

Table 3.6 – MATERIALS FOR VENT PIPING (1)		ABOVEGROUND	
		UNDERGROUND	
1	ABS Pipe and Fittings, Schedule 40 DWV (ASTM D2661)	A	A
2	ABS Pipe - Cellular Core (ASTM F628) and DWV Fittings	A	A
3	Brass Pipe (ASTM B43)	X	A
4	Cast-Iron Soil Pipe and Fittings -Bell and Spigot (ASTM A74)	A	A
5	Cast-Iron Soil Pipe and Fittings -Hubless (CISPI 301, ASTM A888)	A	A
6	Cellular Core PVC DWV Pipe, IPS Schedule 40 (ASTM F891)	A	A
7	Copper Pipe (ASTM B42)	X	A
8	Copper Tube – DWV (ASTM B306) and Copper Drainage Fittings (ASME B16.23)	A	A
9	Copper Tube - K, L, M (ASTM B88) and Copper Drainage Fittings (ASME B16.23)	A	A
10	Galvanized Steel Pipe (ASTM A53) and Cast-Iron Drainage Fittings (ASME B16.12)	X	A
11	PVC Pipe and Fittings, DWV (ASTM D2665)	A	A
12	PVC Schedule 40 Drainage and DWV Fabricated Fittings (ASTM F1866)	A	A
13	Stainless Steel DWV Systems–Type 316L (ASME A112.3.1) (2)	A	A
14	Stainless Steel DWV Systems–Type 304 (ASME A112.3.1) (2)	X	A
15	3.25" OD PVC Pipe and Fittings, DWV (ASTM D2949)	A	A
16	Vitrified Clay Pipe - Extra Strength (ASTM C700)	A	X
		Approved	A A
		Not Approved	X X

NOTES FOR TABLE 3.6

(1) Piping shall be applied within the limits of its listed standards and the manufacturer's recommendations.

(2) Alloy shall be marked on pipe and fittings.