	TABLE 7-3			Inch mm
Drainage Fixture Unit Values (DFU)				1-1/4 32 1-1/2 40
				2 50 2-1/2 65
	Min. Size			3 80
Diversing Appliance Appliance of Figure	Trap and			
Plumbing Appliance, Appurtenance, or Fixture	Trap Arm ⁷	Private	Public	Assembly®
Bathtub or Combination Bath/Shower		2.0	2.0	
Bidet		1.0		
Bidet		2.0	0.0	2.0
Clothes Washer, domestic, standpipe ⁵		3.0	3.0	3.0
Dental Unit, cuspidor		0.0	1.0	1.0
Dishwasher, domestic, with independent drain		2.0	2.0	2.0
Drinking Fountain or Watercooler (per head)		0.5	0.5	1.0
Food-Waste-Grinder, commercial			3.0	3.0
Floor Drain, emergency		0.0	0.0	0.0
Floor Drain (for additional sizes see Section 702)		2.0	2.0	2.0
Shower, single-head trap		2.0	2.0	2.0
Multi-head, each additional		1.0	1.0	1.0
Lavatory, single		1.0	1.0	1.0
Lavatory, in sets of two or three		2.0	2.0	2.0
			2.0	2.0
Washfountain		12.0	3.0	3.0
Mobile Home, trap		12.0	Soo f	ootnote 1,3
Receptor, indirect waste ^{1,3}	I-1/∠			potnote 1,4
Receptor, indirect waste	ວ"		See footnote 1	
Sinks			366 10	Joli lote
Bar	1_1/2"	1.0		
Bar		1.0	2.0	2.0
Clinical			6.0	6.0
Commercial with food waste	-		3.0	3.0
Special Purpose		2.0	3.0	3.0
Special Purpose		3.0	4.0	4.0
Special Purpose		0.0	6.0	6.0
Kitchen, domestic		2.0	2.0	0.0
(with or without food-waste grinder and/or dishw		2.0	2.0	
Laundry		2.0	2.0	2.0
(with or without discharge from a clothes washe		2.0	2.0	2.0
Service or Mop Basin			3.0	3.0
Service or Mop Basin			3.0	3.0
Service, flushing rim			6.0	6.0
Wash, each set of faucets	-		2.0	2.0
Urinal, integral trap 1.0 GPF ²		2.0	2.0	5.0
Urinal, integral trap greater than 1.0 GPF		2.0	2.0	6.0
Urinal, exposed trap		2.0	2.0	5.0
Water Closet, 1.6 GPF Gravity Tank ⁶	3"	3.0	4.0	6.0
Water Closet, 1.6 GPF Flushometer Tank ⁶	3"	3.0	4.0	6.0
Water Closet, 1.6 GPF Flushometer Valve ⁶		3.0	4.0	6.0
Water Closet, greater than 1.6 GPF Gravity Tank ⁶		4.0	6.0	8.0
Water Closet, greater than 1.6 GPF Flushometer Va		4.0	6.0	8.0
, ,				

¹ Indirect waste receptors shall be sized based on the total drainage capacity of the fixtures that drain therein to, in accordance with Table 7-4.

² Provide a 2" (51 mm) minimum drain.

 $[\]ensuremath{^{_{3}}}$ For refrigerators, coffee urns, water stations, and similar low demands.

⁴ For commercial sinks, dishwashers, and similar moderate or heavy demands.

⁵ Buildings having a clothes-washing area with clothes washers in a battery of three (3) or more clothes washers shall be rated at six (6) fixture units each for purposes of sizing common horizontal and vertical drainage piping.

⁶ Water closets shall be computed as six (6) fixture units when determining septic tank sizes based on Appendix K of this code.

⁷ Trap sizes shall not be increased to the point where the fixture discharge may be inadequate to maintain their self-scouring properties.

⁸ Assembly [Public Use (See Table 4-1)].