

1. Project Overview

- **Project Title:** Tenant - Fire Station 209 and 210
 - **Location:** 2691 Sandalwood Parkway East, Brampton, Ontario
 - **Scope of Work:** Mechanical equipment replacement and upgrade, including installation of two new backflow preventers (BFPs).
 - **Permit Application Date:** February 28, 2025
 - **Review Date:** April 3, 2025
 - **Requested By:** City of Brampton – Building Division
-

2. Purpose of this Report

This report is prepared to demonstrate compliance with the City's Notice of Building Review Deficiencies dated April 3, 2025. Specifically, it addresses the requirement to prove that the installation of new backflow preventers will **not adversely impact** the performance of the existing sprinkler systems at Fire Stations 209 and 210.

3. Systems Reviewed

- Wet Pipe Sprinkler System
- Dry Pipe Sprinkler System

Hydraulic calculations were conducted for both systems, before and after the installation of the new backflow preventers.

4. Hydraulic Analysis Summary

4.1 Wet Pipe Sprinkler System

| Item | Without BFP | With BFP |
|--------------------|-------------|-----------|
| Total Flow Demand | 273.5 GPM | 273.5 GPM |
| Available Pressure | 59.7 psi | 59.7 psi |
| Required Pressure | 46.8 psi | 51.7 psi |
| Pressure Margin | +12.9 psi | +8.0 psi |

Result: Even after including a 5 psi pressure loss from the BFP, the available pressure exceeds the required pressure by 8.0 psi.

Conclusion:

No negative impact on the wet sprinkler system.

4.2 Dry Pipe Sprinkler System

4.2.1 Hydraulic Analysis without Riser Modification (Original System)

| Item | Value |
|--------------------|-----------|
| Total Flow Demand | 355.0 GPM |
| Available Pressure | 59.4 psi |
| Required Pressure | 61.8 psi |
| Pressure Margin | -2.4 psi |

Observation:

- After including the backflow preventer's pressure loss (~5 psi), the available pressure (59.4 psi) is insufficient to meet the required pressure (61.8 psi).
- This results in a deficit of 2.4 psi.

Conclusion:

In the original configuration, the installation of the new backflow **preventer negatively impacts** the dry sprinkler system's hydraulic performance.

4.2.2 Hydraulic Analysis after **Riser Modification (Upgrading to 4" Riser)**

| Item | Value |
|--------------------|-----------|
| Total Flow Demand | 355.0 GPM |
| Available Pressure | 59.4 psi |
| Required Pressure | 53.9 psi |
| Pressure Margin | +5.5 psi |

Observation:

- By increasing the riser size from 3" to 4", the frictional losses were reduced.
- The system now requires only 53.9 psi to satisfy the sprinkler demand.
- The available pressure (59.4 psi) exceeds the required pressure by a margin of 5.5 psi.

Conclusion:

After upgrading the riser to 4", the installation of the backflow preventers no longer negatively affects the dry sprinkler system. Adequate pressure is available to meet system demand in compliance with NFPA 13.

5. Backflow Preventer Details

- **Model:** Watts 350DA
 - **Type:** Double Check Detector Assembly (DCDA)
 - **Size:** 8 inch
 - **Pressure Loss at 355 GPM:** Approximately 5 psi (as per manufacturer's published data)
-

6. Conclusion

Based on the revised hydraulic calculations and system modifications, it is confirmed that:

- The installation of the new backflow preventers does not adversely affect the hydraulic performance of either the wet pipe or dry pipe sprinkler systems.
- The sprinkler systems remain compliant with the performance criteria established by **NFPA 13** and the requirements outlined by the City of Brampton.

Thus, the deficiency noted by the City of Brampton has been successfully addressed.

7. Attachments

- Hydraulic Calculations – Wet System (Before and After BFP Installation)
- Hydraulic Calculations – Dry System (Before and After BFP Installation, and After Riser Upgrade)
- Backflow Preventer Datasheets (Watts 350DA)
- Original Notice of Building Review Deficiencies (City of Brampton Letter)
- Wet System Isometric
- Dry System Isometric

Hydraulic Calculations

Project Name: TENANT - FIRE STATION 209 & 210

DESIGN DATA:

Remote Area Location: Ground Floor

System Type: Wet

Hazard: Ordinary Hazard Group-1

Design Density: 0.15 gpm/ sq. ft

Remote Area: Maximum 1500 SQ. FT

Number of Sprinklers in Remote Area: 12 Nos

Sprinkler Classification: Quick Response Sprinklers

Maximum Sprinkler Coverage: 130 sq. ft

Sprinkler K-Factor: K5.6

CALCULATING END SPRINKLER FLOW IN REMOTE AREA

Design Density = 0.15 gpm/sq ft

Maximum area covered by one sprinkler = 130 sq. ft

Flow required at end sprinkler = 0.15 x 130 gpm

$$= 19.5 \text{ gpm}$$

CALCULATING END SPRINKLER PRESSURE

Using equation.

$$Q = K \times \sqrt{P}$$

Where, Q = Flow in gpm (gallons per minute)

K = Sprinkler constant given by manufacture data sheet

P = Pressure at sprinkler in psi (pound per square inch)

Once the flow (Q) is calculated, the required pressure (P) can be calculated by simply rearranging the above formula:

$$P = \left(\frac{Q}{k}\right)^2$$

$$Q = 19.5 \text{ gpm}$$

$$K = 5.6$$

Therefore, Pressure required at end sprinkler = $(19.5/5.6)^2 = 12.12 \text{ psi}$.

Therefore, our calculation shall start at Pressure P = 12.12 psi.

DATE: 4/28/20254.HYDRAULICCALCULATIONS\WORKING\WET SYSTEM WITHOUT BFP.SDF

JOB TITLE:

WATER SUPPLY DATA

| SOURCE NODE TAG | STATIC PRESS. (PSI) | RESID. PRESS. (PSI) | FLOW @ (GPM) | AVAIL. PRESS. (PSI) | TOTAL @ DEMAND (GPM) | REQ'D PRESS. (PSI) |
|-----------------------|---------------------------|---------------------------|--------------------|---------------------------|-------------------------------|--------------------------|
| SRC | 60.0 | 55.0 | 1160.0 | 59.7 | 273.5 | 46.8 |

AGGREGATE FLOW ANALYSIS:

| | |
|--|-----------|
| TOTAL FLOW AT SOURCE | 273.5 GPM |
| TOTAL HOSE STREAM ALLOWANCE AT SOURCE | 0.0 GPM |
| OTHER HOSE STREAM ALLOWANCES | 0.0 GPM |
| TOTAL DISCHARGE FROM ACTIVE SPRINKLERS | 273.5 GPM |

NODE ANALYSIS DATA

| NODE TAG | ELEVATION (FT) | NODE TYPE | PRESSURE (PSI) | DISCHARGE (GPM) |
|----------|-------------------|-----------|-------------------|--------------------|
| S1 | 17.0 | K= 5.60 | 12.3 | 19.6 |
| S2 | 17.0 | K= 5.60 | 13.9 | 20.9 |
| S3 | 17.0 | K= 5.60 | 13.1 | 20.3 |
| S4 | 17.0 | K= 5.60 | 12.1 | 19.5 |
| S5 | 17.0 | K= 5.60 | 17.4 | 23.4 |
| S6 | 17.0 | K= 5.60 | 19.6 | 24.8 |
| S7 | 17.0 | K= 5.60 | 16.0 | 22.4 |
| S8 | 17.0 | K= 5.60 | 14.8 | 21.5 |
| S9 | 17.0 | K= 5.60 | 19.3 | 24.6 |
| S10 | 17.0 | K= 5.60 | 21.8 | 26.1 |
| S11 | 17.0 | K= 5.60 | 21.1 | 25.7 |
| S12 | 17.0 | K= 5.60 | 19.2 | 24.5 |
| 20 | 17.0 | - - - - | 17.7 | - - - |
| 21 | 17.0 | - - - - | 21.5 | - - - |
| 22 | 17.0 | - - - - | 26.1 | - - - |
| 23 | 17.0 | - - - - | 31.3 | - - - |
| 24 | 17.0 | - - - - | 34.5 | - - - |
| 25 | 17.0 | - - - - | 35.3 | - - - |
| 26 | 17.0 | - - - - | 35.7 | - - - |
| 27 | 2.0 | - - - - | 43.6 | - - - |
| 28 | 2.0 | - - - - | 43.6 | - - - |
| 29 | 0.0 | - - - - | 44.5 | - - - |
| 30 | 0.0 | - - - - | 44.5 | - - - |
| 31 | 0.0 | - - - - | 44.5 | - - - |
| SRC | -5.0 | SOURCE | 46.8 | 273.5 |

DATE: 4/28/20254.HYDRAULICCALCULATIONS\WORKING\WET SYSTEM WITHOUT BFP.SDF

JOB TITLE:

PIPE DATA

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | |
|----------|----------|-------|------|-------|-------|-----------|-----------------|--------|--------|-----|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) FL/FT | (FT) | SUM. | |
| | | | | | | | | | (PSI) | |
| | Pipe: 1 | | | | | -19.6 | 1.049 PL | 13.00 | PF | 1.6 |
| S1 | | 17.0 | 5.6 | 12.3 | 19.6 | 7.3 | 120 FTG | ---- | PE | 0.0 |
| S2 | | 17.0 | 5.6 | 13.9 | 20.9 | | 0.126 TL | 13.00 | PV | |
| | Pipe: 2 | | | | | -40.6 | 1.049 PL | 2.80 | PF | 3.8 |
| S2 | | 17.0 | 5.6 | 13.9 | 20.9 | 15.1 | 120 FTG | T | PE | 0.0 |
| 20 | | 17.0 | 0.0 | 17.7 | 0.0 | | 0.481 TL | 7.80 | PV | |
| | Pipe: 3 | | | | | -19.5 | 1.049 PL | 8.16 | PF | 1.0 |
| S4 | | 17.0 | 5.6 | 12.1 | 19.5 | 7.2 | 120 FTG | ---- | PE | 0.0 |
| S3 | | 17.0 | 5.6 | 13.1 | 20.3 | | 0.124 TL | 8.16 | PV | |
| | Pipe: 4 | | | | | -39.8 | 1.049 PL | 9.82 | PF | 4.6 |
| S3 | | 17.0 | 5.6 | 13.1 | 20.3 | 14.8 | 120 FTG | ---- | PE | 0.0 |
| 20 | | 17.0 | 0.0 | 17.7 | 0.0 | | 0.465 TL | 9.82 | PV | |
| | Pipe: 5 | | | | | -23.4 | 1.049 PL | 13.00 | PF | 2.3 |
| S5 | | 17.0 | 5.6 | 17.4 | 23.4 | 8.7 | 120 FTG | ---- | PE | 0.0 |
| S6 | | 17.0 | 5.6 | 19.6 | 24.8 | | 0.173 TL | 13.00 | PV | |
| | Pipe: 6 | | | | | -48.2 | 1.049 PL | 2.80 | PF | 1.9 |
| S6 | | 17.0 | 5.6 | 19.6 | 24.8 | 17.9 | 120 FTG | ---- | PE | 0.0 |
| 21 | | 17.0 | 0.0 | 21.5 | 0.0 | | 0.662 TL | 2.80 | PV | |
| | Pipe: 7 | | | | | -21.5 | 1.049 PL | 8.16 | PF | 1.2 |
| S8 | | 17.0 | 5.6 | 14.8 | 21.5 | 8.0 | 120 FTG | ---- | PE | 0.0 |
| S7 | | 17.0 | 5.6 | 16.0 | 22.4 | | 0.149 TL | 8.16 | PV | |
| | Pipe: 8 | | | | | -44.0 | 1.049 PL | 9.82 | PF | 5.5 |
| S7 | | 17.0 | 5.6 | 16.0 | 22.4 | 16.3 | 120 FTG | ---- | PE | 0.0 |
| 21 | | 17.0 | 0.0 | 21.5 | 0.0 | | 0.558 TL | 9.82 | PV | |
| | Pipe: 9 | | | | | -80.3 | 1.610 PL | 10.00 | PF | 3.8 |
| 20 | | 17.0 | 0.0 | 17.7 | 0.0 | 12.7 | 120 FTG | T | PE | 0.0 |
| 21 | | 17.0 | 0.0 | 21.5 | 0.0 | | 0.212 TL | 18.00 | PV | |
| | Pipe: 10 | | | | | -24.6 | 1.049 PL | 13.00 | PF | 2.5 |
| S9 | | 17.0 | 5.6 | 19.3 | 24.6 | 9.1 | 120 FTG | ---- | PE | 0.0 |
| S10 | | 17.0 | 5.6 | 21.8 | 26.1 | | 0.191 TL | 13.00 | PV | |
| | Pipe: 11 | | | | | -50.7 | 1.049 PL | 6.00 | PF | 4.4 |
| S10 | | 17.0 | 5.6 | 21.8 | 26.1 | 18.8 | 120 FTG | ---- | PE | 0.0 |
| 22 | | 17.0 | 0.0 | 26.1 | 0.0 | | 0.727 TL | 6.00 | PV | |
| | Pipe: 12 | | | | | -24.5 | 1.049 PL | 10.00 | PF | 1.9 |
| S12 | | 17.0 | 5.6 | 19.2 | 24.5 | 9.1 | 120 FTG | ---- | PE | 0.0 |
| S11 | | 17.0 | 5.6 | 21.1 | 25.7 | | 0.190 TL | 10.00 | PV | |
| | Pipe: 13 | | | | | -50.3 | 1.049 PL | 7.00 | PF | 5.0 |
| S11 | | 17.0 | 5.6 | 21.1 | 25.7 | 18.7 | 120 FTG | ---- | PE | 0.0 |
| 22 | | 17.0 | 0.0 | 26.1 | 0.0 | | 0.716 TL | 7.00 | PV | |
| | Pipe: 14 | | | | | -172.5 | 2.067 PL | 7.91 | PF | 4.6 |
| 21 | | 17.0 | 0.0 | 21.5 | 0.0 | 16.5 | 120 FTG | T | PE | 0.0 |
| 22 | | 17.0 | 0.0 | 26.1 | 0.0 | | 0.258 TL | 17.91 | PV | |

DATE: 4/28/20254.HYDRAULICCALCULATIONS\WORKING\WET SYSTEM WITHOUT BFP.SDF

JOB TITLE:


| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | |
|----------|-------|-------|------|-------|-------|-----------|----------|--------|--------|---------|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) | (FT) | SUM. | |
| | | | | | | | FL/FT | | (PSI) | |
| Pipe: 15 | | | | | | -273.4 | 2.469 | PL | 20.22 | PF 5.1 |
| 22 | | 17.0 | 0.0 | 26.1 | 0.0 | 18.3 | 120 | FTG | ---- | PE 0.0 |
| 23 | | 17.0 | 0.0 | 31.3 | 0.0 | | 0.254 | TL | 20.22 | PV |
| Pipe: 16 | | | | | | -273.4 | 3.068 | PL | 30.00 | PF 3.3 |
| 23 | | 17.0 | 0.0 | 31.3 | 0.0 | 11.9 | 120 | FTG | E | PE 0.0 |
| 24 | | 17.0 | 0.0 | 34.5 | 0.0 | | 0.088 | TL | 37.00 | PV |
| Pipe: 17 | | | | | | -273.4 | 4.026 | PL | 24.82 | PF 0.8 |
| 24 | | 17.0 | 0.0 | 34.5 | 0.0 | 6.9 | 120 | FTG | E | PE 0.0 |
| 25 | | 17.0 | 0.0 | 35.3 | 0.0 | | 0.023 | TL | 34.82 | PV |
| Pipe: 18 | | | | | | -273.4 | 4.026 | PL | 5.00 | PF 0.4 |
| 25 | | 17.0 | 0.0 | 35.3 | 0.0 | 6.9 | 120 | FTG | E | PE 0.0 |
| 26 | | 17.0 | 0.0 | 35.7 | 0.0 | | 0.023 | TL | 15.00 | PV |
| Pipe: 19 | | | | | | 273.4 | 4.026 | PL | 15.00 | PF 1.4 |
| 27 | | 2.0 | 0.0 | 43.6 | 0.0 | 6.9 | 120 | FTG | TCG | PE -6.5 |
| 26 | | 17.0 | 0.0 | 35.7 | 0.0 | | 0.023 | TL | 59.00 | PV |
| Pipe: 20 | | | | | | -273.4 | 7.981 | PL | 2.00 | PF 0.0 |
| 27 | | 2.0 | 0.0 | 43.6 | 0.0 | 1.8 | 120 | FTG | E | PE 0.0 |
| 28 | | 2.0 | 0.0 | 43.6 | 0.0 | | 0.001 | TL | 20.00 | PV |
| Pipe: 21 | | | | | | -273.4 | 7.981 | PL | 2.00 | PF 0.0 |
| 28 | | 2.0 | 0.0 | 43.6 | 0.0 | 1.8 | 120 | FTG | E | PE 0.9 |
| 29 | | 0.0 | 0.0 | 44.5 | 0.0 | | 0.001 | TL | 20.00 | PV |
| Pipe: 22 | | | | | | -273.4 | 7.981 | PL | 7.00 | PF 0.0 |
| 29 | | 0.0 | 0.0 | 44.5 | 0.0 | 1.8 | 120 | FTG | E | PE 0.0 |
| 30 | | 0.0 | 0.0 | 44.5 | 0.0 | | 0.001 | TL | 25.00 | PV |
| Pipe: 23 | | | | | | -273.4 | 7.981 | PL | 5.00 | PF 0.0 |
| 30 | | 0.0 | 0.0 | 44.5 | 0.0 | 1.8 | 120 | FTG | E | PE 0.0 |
| 31 | | 0.0 | 0.0 | 44.5 | 0.0 | | 0.001 | TL | 23.00 | PV |
| Pipe: 24 | | | | | | -273.5 | 7.981 | PL | 82.00 | PF 0.1 |
| 31 | | 0.0 | 0.0 | 44.5 | 0.0 | 1.8 | 120 | FTG | ---- | PE 2.2 |
| SRC | | -5.0 | SRCE | 46.8 | (N/A) | | 0.001 | TL | 82.00 | PV |

NOTES (HASS):

- (1) Calculations were performed by the HASS computer program in accordance with NFPA (2020) under license no. 65699794 granted by
 HRS Systems, Inc.
 208 Southside Square
 Petersburg, TN 37144
 (931) 659-9760
- (2) The system has been calculated to provide an average imbalance at each node of 0.002 gpm and a maximum imbalance at any node of 0.059 gpm.
- (3) Total pressure at each node is used in balancing the system. Maximum water velocity is 18.8 ft/sec at pipe 11.
- (4) Items listed in bold print on the cover sheet

WATER SUPPLY ANALYSIS

Static: 60.00 psi Resid: 55.00 psi Flow: 1160.0 gpm



DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\WET SYSTEM INCLUDING BFP.SDF

JOB TITLE:

WATER SUPPLY DATA

| SOURCE NODE TAG | STATIC PRESS. (PSI) | RESID. PRESS. (PSI) | FLOW @ (GPM) | AVAIL. PRESS. (PSI) | TOTAL @ DEMAND (GPM) | REQ'D PRESS. (PSI) |
|-----------------------|---------------------------|---------------------------|--------------------|---------------------------|-------------------------------|--------------------------|
| SRC | 60.0 | 55.0 | 1160.0 | 59.7 | 273.5 | 51.7 |

AGGREGATE FLOW ANALYSIS:

| | |
|--|-----------|
| TOTAL FLOW AT SOURCE | 273.5 GPM |
| TOTAL HOSE STREAM ALLOWANCE AT SOURCE | 0.0 GPM |
| OTHER HOSE STREAM ALLOWANCES | 0.0 GPM |
| TOTAL DISCHARGE FROM ACTIVE SPRINKLERS | 273.5 GPM |

NODE ANALYSIS DATA

| NODE TAG | ELEVATION (FT) | NODE TYPE | PRESSURE (PSI) | DISCHARGE (GPM) |
|----------|-------------------|-----------|-------------------|--------------------|
| S1 | 17.0 | K= 5.60 | 12.3 | 19.6 |
| S2 | 17.0 | K= 5.60 | 13.9 | 20.9 |
| S3 | 17.0 | K= 5.60 | 13.1 | 20.3 |
| S4 | 17.0 | K= 5.60 | 12.1 | 19.5 |
| S5 | 17.0 | K= 5.60 | 17.4 | 23.4 |
| S6 | 17.0 | K= 5.60 | 19.6 | 24.8 |
| S7 | 17.0 | K= 5.60 | 16.0 | 22.4 |
| S8 | 17.0 | K= 5.60 | 14.8 | 21.5 |
| S9 | 17.0 | K= 5.60 | 19.3 | 24.6 |
| S10 | 17.0 | K= 5.60 | 21.8 | 26.1 |
| S11 | 17.0 | K= 5.60 | 21.1 | 25.7 |
| S12 | 17.0 | K= 5.60 | 19.2 | 24.5 |
| 20 | 17.0 | - - - - | 17.7 | - - - |
| 21 | 17.0 | - - - - | 21.5 | - - - |
| 22 | 17.0 | - - - - | 26.1 | - - - |
| 23 | 17.0 | - - - - | 31.3 | - - - |
| 24 | 17.0 | - - - - | 34.5 | - - - |
| 25 | 17.0 | - - - - | 35.3 | - - - |
| 26 | 17.0 | - - - - | 35.7 | - - - |
| 27 | 2.0 | - - - - | 43.6 | - - - |
| 28 | 2.0 | - - - - | 43.6 | - - - |
| 29 | 0.0 | - - - - | 44.5 | - - - |
| BFP-IN | 0.0 | - - - - | 49.5 | - - - |
| BFP-OUT | 0.0 | - - - - | 44.5 | - - - |
| 30 | 0.0 | - - - - | 49.5 | - - - |
| 31 | 0.0 | - - - - | 49.5 | - - - |
| SRC | -5.0 | SOURCE | 51.7 | 273.5 |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\WET SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

PIPE DATA

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | |
|----------|----------|-------|------|-------|-------|-----------|-----------------|--------|--------|-----|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) FL/FT | (FT) | SUM. | |
| | | | | | | | | | (PSI) | |
| | Pipe: 1 | | | | | -19.6 | 1.049 PL | 13.00 | PF | 1.6 |
| S1 | | 17.0 | 5.6 | 12.3 | 19.6 | 7.3 | 120 FTG | ---- | PE | 0.0 |
| S2 | | 17.0 | 5.6 | 13.9 | 20.9 | | 0.126 TL | 13.00 | PV | |
| | Pipe: 2 | | | | | -40.6 | 1.049 PL | 2.80 | PF | 3.8 |
| S2 | | 17.0 | 5.6 | 13.9 | 20.9 | 15.1 | 120 FTG | T | PE | 0.0 |
| 20 | | 17.0 | 0.0 | 17.7 | 0.0 | | 0.481 TL | 7.80 | PV | |
| | Pipe: 3 | | | | | -19.5 | 1.049 PL | 8.16 | PF | 1.0 |
| S4 | | 17.0 | 5.6 | 12.1 | 19.5 | 7.2 | 120 FTG | ---- | PE | 0.0 |
| S3 | | 17.0 | 5.6 | 13.1 | 20.3 | | 0.124 TL | 8.16 | PV | |
| | Pipe: 4 | | | | | -39.8 | 1.049 PL | 9.82 | PF | 4.6 |
| S3 | | 17.0 | 5.6 | 13.1 | 20.3 | 14.8 | 120 FTG | ---- | PE | 0.0 |
| 20 | | 17.0 | 0.0 | 17.7 | 0.0 | | 0.465 TL | 9.82 | PV | |
| | Pipe: 5 | | | | | -23.4 | 1.049 PL | 13.00 | PF | 2.3 |
| S5 | | 17.0 | 5.6 | 17.4 | 23.4 | 8.7 | 120 FTG | ---- | PE | 0.0 |
| S6 | | 17.0 | 5.6 | 19.6 | 24.8 | | 0.173 TL | 13.00 | PV | |
| | Pipe: 6 | | | | | -48.2 | 1.049 PL | 2.80 | PF | 1.9 |
| S6 | | 17.0 | 5.6 | 19.6 | 24.8 | 17.9 | 120 FTG | ---- | PE | 0.0 |
| 21 | | 17.0 | 0.0 | 21.5 | 0.0 | | 0.662 TL | 2.80 | PV | |
| | Pipe: 7 | | | | | -21.5 | 1.049 PL | 8.16 | PF | 1.2 |
| S8 | | 17.0 | 5.6 | 14.8 | 21.5 | 8.0 | 120 FTG | ---- | PE | 0.0 |
| S7 | | 17.0 | 5.6 | 16.0 | 22.4 | | 0.149 TL | 8.16 | PV | |
| | Pipe: 8 | | | | | -44.0 | 1.049 PL | 9.82 | PF | 5.5 |
| S7 | | 17.0 | 5.6 | 16.0 | 22.4 | 16.3 | 120 FTG | ---- | PE | 0.0 |
| 21 | | 17.0 | 0.0 | 21.5 | 0.0 | | 0.558 TL | 9.82 | PV | |
| | Pipe: 9 | | | | | -80.3 | 1.610 PL | 10.00 | PF | 3.8 |
| 20 | | 17.0 | 0.0 | 17.7 | 0.0 | 12.7 | 120 FTG | T | PE | 0.0 |
| 21 | | 17.0 | 0.0 | 21.5 | 0.0 | | 0.212 TL | 18.00 | PV | |
| | Pipe: 10 | | | | | -24.6 | 1.049 PL | 13.00 | PF | 2.5 |
| S9 | | 17.0 | 5.6 | 19.3 | 24.6 | 9.1 | 120 FTG | ---- | PE | 0.0 |
| S10 | | 17.0 | 5.6 | 21.8 | 26.1 | | 0.191 TL | 13.00 | PV | |
| | Pipe: 11 | | | | | -50.7 | 1.049 PL | 6.00 | PF | 4.4 |
| S10 | | 17.0 | 5.6 | 21.8 | 26.1 | 18.8 | 120 FTG | ---- | PE | 0.0 |
| 22 | | 17.0 | 0.0 | 26.1 | 0.0 | | 0.727 TL | 6.00 | PV | |
| | Pipe: 12 | | | | | -24.5 | 1.049 PL | 10.00 | PF | 1.9 |
| S12 | | 17.0 | 5.6 | 19.2 | 24.5 | 9.1 | 120 FTG | ---- | PE | 0.0 |
| S11 | | 17.0 | 5.6 | 21.1 | 25.7 | | 0.190 TL | 10.00 | PV | |
| | Pipe: 13 | | | | | -50.3 | 1.049 PL | 7.00 | PF | 5.0 |
| S11 | | 17.0 | 5.6 | 21.1 | 25.7 | 18.7 | 120 FTG | ---- | PE | 0.0 |
| 22 | | 17.0 | 0.0 | 26.1 | 0.0 | | 0.716 TL | 7.00 | PV | |
| | Pipe: 14 | | | | | -172.5 | 2.067 PL | 7.91 | PF | 4.6 |
| 21 | | 17.0 | 0.0 | 21.5 | 0.0 | 16.5 | 120 FTG | T | PE | 0.0 |
| 22 | | 17.0 | 0.0 | 26.1 | 0.0 | | 0.258 TL | 17.91 | PV | |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\WET SYSTEM INCLUDING BFP.SDF
 JOB TITLE:


| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | |
|----------|------|-------|-------|-------|-----------|---------|----------|--------|--------|----------------------------|
| NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) | FL/FT | (FT) | SUM. | |
| | | | | | | | | | (PSI) | |
| Pipe: 15 | | | | | | -273.4 | 2.469 | PL | 20.22 | PF 5.1 |
| 22 | 17.0 | 0.0 | 26.1 | 0.0 | 18.3 | 120 | FTG | ---- | PE | 0.0 |
| 23 | 17.0 | 0.0 | 31.3 | 0.0 | | 0.254 | TL | 20.22 | PV | |
| Pipe: 16 | | | | | | -273.4 | 3.068 | PL | 30.00 | PF 3.3 |
| 23 | 17.0 | 0.0 | 31.3 | 0.0 | 11.9 | 120 | FTG | E | PE | 0.0 |
| 24 | 17.0 | 0.0 | 34.5 | 0.0 | | 0.088 | TL | 37.00 | PV | |
| Pipe: 17 | | | | | | -273.4 | 4.026 | PL | 24.82 | PF 0.8 |
| 24 | 17.0 | 0.0 | 34.5 | 0.0 | 6.9 | 120 | FTG | E | PE | 0.0 |
| 25 | 17.0 | 0.0 | 35.3 | 0.0 | | 0.023 | TL | 34.82 | PV | |
| Pipe: 18 | | | | | | -273.4 | 4.026 | PL | 5.00 | PF 0.4 |
| 25 | 17.0 | 0.0 | 35.3 | 0.0 | 6.9 | 120 | FTG | E | PE | 0.0 |
| 26 | 17.0 | 0.0 | 35.7 | 0.0 | | 0.023 | TL | 15.00 | PV | |
| Pipe: 19 | | | | | | 273.4 | 4.026 | PL | 15.00 | PF 1.4 |
| 27 | 2.0 | 0.0 | 43.6 | 0.0 | 6.9 | 120 | FTG | TCG | PE | -6.5 |
| 26 | 17.0 | 0.0 | 35.7 | 0.0 | | 0.023 | TL | 59.00 | PV | |
| Pipe: 20 | | | | | | -273.4 | 7.981 | PL | 2.00 | PF 0.0 |
| 27 | 2.0 | 0.0 | 43.6 | 0.0 | 1.8 | 120 | FTG | E | PE | 0.0 |
| 28 | 2.0 | 0.0 | 43.6 | 0.0 | | 0.001 | TL | 20.00 | PV | |
| Pipe: 21 | | | | | | -273.4 | 7.981 | PL | 2.00 | PF 0.0 |
| 28 | 2.0 | 0.0 | 43.6 | 0.0 | 1.8 | 120 | FTG | E | PE | 0.9 |
| 29 | 0.0 | 0.0 | 44.5 | 0.0 | | 0.001 | TL | 20.00 | PV | |
| Pipe: 22 | | | | | | -273.4 | 7.981 | PL | 2.00 | PF 0.0 |
| 29 | 0.0 | 0.0 | 44.5 | 0.0 | 1.8 | 120 | FTG | ---- | PE | 0.0 |
| BFP-OUT | 0.0 | 0.0 | 44.5 | 0.0 | | 0.001 | TL | 2.00 | PV | |
| Pipe: 23 | | | | | | | | | | |
| BFP-IN | 0.0 | 0.0 | 49.5 | 0.0 | | 5.0 | psi, | 273.4 | gpm | FIXED PRESSURE LOSS DEVICE |
| BFP-OUT | 0.0 | 0.0 | 44.5 | 0.0 | | | | | | |
| Pipe: 24 | | | | | | -273.4 | 7.981 | PL | 3.00 | PF 0.0 |
| BFP-IN | 0.0 | 0.0 | 49.5 | 0.0 | 1.8 | 120 | FTG | ---- | PE | 0.0 |
| 30 | 0.0 | 0.0 | 49.5 | 0.0 | | 0.001 | TL | 3.00 | PV | |
| Pipe: 25 | | | | | | -273.4 | 7.981 | PL | 5.00 | PF 0.0 |
| 30 | 0.0 | 0.0 | 49.5 | 0.0 | 1.8 | 120 | FTG | E | PE | 0.0 |
| 31 | 0.0 | 0.0 | 49.5 | 0.0 | | 0.001 | TL | 23.00 | PV | |
| Pipe: 26 | | | | | | -273.5 | 7.981 | PL | 82.00 | PF 0.1 |
| 31 | 0.0 | 0.0 | 49.5 | 0.0 | 1.8 | 120 | FTG | ---- | PE | 2.2 |
| SRC | -5.0 | SRCE | 51.7 | (N/A) | | 0.001 | TL | 82.00 | PV | |

NOTES (HASS):


- (1) Calculations were performed by the HASS computer program in accordance with NFPA (2020) under license no. 65699794 granted by HRS Systems, Inc. 208 Southside Square Petersburg, TN 37144 (931) 659-9760

WATER SUPPLY ANALYSIS

Static: 60.00 psi Resid: 55.00 psi Flow: 1160.0 gpm



WATER SUPPLY CURVE



Hydraulic Calculations

Project Name: TENANT - FIRE STATION 209 & 210

DESIGN DATA:

Remote Area Location: Attic Floor

System Type: Dry System

Hazard: Ordinary Hazard Group-1

Design Density: 0.15 gpm/ sq. ft

Remote Area: Maximum 1950 SQ. FT (1500 sq.ft times 1.3)

Sprinkler Classification: Quick Response Upright

Maximum Sprinkler Coverage: 130 sq. ft

Sprinkler K-Factor: K5.6

CALCULATING END SPRINKLER FLOW IN REMOTE AREA

Design Density = 0.15 gpm/sq ft

Maximum area covered by one sprinkler = 130 sq. ft

Flow required at end sprinkler = 0.15 x 130 gpm

$$= 19.5 \text{ gpm}$$

CALCULATING END SPRINKLER PRESSURE

Using equation.

$$Q = K \times \sqrt{P}$$

Where, Q = Flow in gpm (gallons per minute)

K = Sprinkler constant given by manufacture data sheet

P = Pressure at sprinkler in psi (pound per square inch)

Once the flow (Q) is calculated, the required pressure (P) can be calculated by simply rearranging the above formula:

$$P = \left(\frac{Q}{K}\right)^2$$

$$Q = 19.5 \text{ gpm}$$

$$K = 5.6$$

Therefore, Pressure required at end sprinkler = $(19.5/5.6)^2 = 12.12 \text{ psi}$.

Therefore, our calculation shall start at Pressure P = 12.12 psi.

This pressure shall be inserted into hydraulic calculation software of minimum end conditions.

DATE: 4/28/20254.HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM WITHOUT BFP.SDF

JOB TITLE:

WATER SUPPLY DATA

| SOURCE NODE TAG | STATIC PRESS. (PSI) | RESID. PRESS. (PSI) | FLOW @ (GPM) | AVAIL. PRESS. (PSI) | TOTAL @ DEMAND (GPM) | REQ'D PRESS. (PSI) |
|-----------------------|---------------------------|---------------------------|--------------------|---------------------------|-------------------------------|--------------------------|
| SRC | 60.0 | 55.0 | 1160.0 | 59.4 | 355.0 | 56.8 |

AGGREGATE FLOW ANALYSIS:

| | |
|--|-----------|
| TOTAL FLOW AT SOURCE | 355.0 GPM |
| TOTAL HOSE STREAM ALLOWANCE AT SOURCE | 0.0 GPM |
| OTHER HOSE STREAM ALLOWANCES | 0.0 GPM |
| TOTAL DISCHARGE FROM ACTIVE SPRINKLERS | 355.0 GPM |

NODE ANALYSIS DATA

| NODE TAG | ELEVATION (FT) | NODE TYPE | PRESSURE (PSI) | DISCHARGE (GPM) |
|----------|-------------------|-----------|-------------------|--------------------|
| S1 | 32.0 | K= 5.60 | 15.9 | 22.4 |
| S2 | 32.0 | K= 5.60 | 18.2 | 23.9 |
| S3 | 32.0 | K= 5.60 | 19.6 | 24.8 |
| S4 | 32.0 | K= 5.60 | 19.7 | 24.8 |
| S5 | 32.0 | K= 5.60 | 16.6 | 22.8 |
| S6 | 32.0 | K= 5.60 | 18.5 | 24.1 |
| S7 | 32.0 | K= 5.60 | 12.1 | 19.5 |
| S8 | 32.0 | K= 5.60 | 13.9 | 20.8 |
| S9 | 32.0 | K= 5.60 | 19.3 | 24.6 |
| S10 | 32.0 | K= 5.60 | 16.8 | 22.9 |
| S11 | 32.0 | K= 5.60 | 18.7 | 24.2 |
| S12 | 32.0 | K= 5.60 | 18.1 | 23.9 |
| S13 | 32.0 | K= 5.60 | 20.7 | 25.5 |
| S14 | 32.0 | K= 5.60 | 20.9 | 25.6 |
| S15 | 32.0 | K= 5.60 | 20.3 | 25.2 |
| 20 | 32.0 | - - - - | 20.8 | - - - |
| 21 | 32.0 | - - - - | 20.3 | - - - |
| 22 | 32.0 | - - - - | 20.1 | - - - |
| 23 | 32.0 | - - - - | 20.1 | - - - |
| 24 | 32.0 | - - - - | 20.2 | - - - |
| 25 | 32.0 | - - - - | 20.3 | - - - |
| 26 | 32.0 | - - - - | 20.4 | - - - |
| 27 | 32.0 | - - - - | 20.7 | - - - |
| 28 | 32.0 | - - - - | 22.2 | - - - |
| 29 | 32.0 | - - - - | 22.8 | - - - |
| 30 | 32.0 | - - - - | 23.6 | - - - |
| 31 | 32.0 | - - - - | 24.2 | - - - |
| 32 | 32.0 | - - - - | 25.6 | - - - |
| 33 | 32.0 | - - - - | 26.7 | - - - |
| 34 | 32.0 | - - - - | 27.5 | - - - |
| 35 | 32.0 | - - - - | 28.3 | - - - |
| 36 | 32.0 | - - - - | 28.9 | - - - |
| 37 | 32.0 | - - - - | 22.8 | - - - |
| 38 | 32.0 | - - - - | 21.7 | - - - |
| 39 | 32.0 | - - - - | 21.3 | - - - |
| 40 | 32.0 | - - - - | 30.4 | - - - |
| 41 | 2.0 | - - - - | 53.5 | - - - |
| 42 | 2.0 | - - - - | 53.6 | - - - |
| 43 | 2.0 | - - - - | 53.6 | - - - |
| 44 | 0.0 | - - - - | 54.5 | - - - |
| 45 | 0.0 | - - - - | 54.5 | - - - |

DATE: 4/28/20254.HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM WITHOUT BFP.SDF

JOB TITLE:

NODE ANALYSIS DATA

| NODE TAG | ELEVATION (FT) | NODE TYPE | PRESSURE (PSI) | DISCHARGE (GPM) |
|----------|-------------------|-----------|-------------------|--------------------|
| 46 | -5.0 | - - - - | 56.7 | - - - |
| SRC | -5.0 | SOURCE | 56.8 | 355.0 |

DATE: 4/28/20254.HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM WITHOUT BFP.SDF
 JOB TITLE:

PIPE DATA

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | | |
|----------|----------|-------|------|-------|-------|-----------|-----------------|--------|--------|----|-----|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) FL/FT | (FT) | SUM. | | |
| | | | | | | | | | (PSI) | | |
| | Pipe: 1 | | | | | -22.4 | 1.049 | PL | 10.00 | PF | 2.2 |
| S1 | | 32.0 | 5.6 | 15.9 | 22.4 | 8.3 | 100 | FTG | ---- | PE | 0.0 |
| S2 | | 32.0 | 5.6 | 18.2 | 23.9 | | 0.224 | TL | 10.00 | PV | |
| | Pipe: 2 | | | | | -46.2 | 1.049 | PL | 3.00 | PF | 2.6 |
| S2 | | 32.0 | 5.6 | 18.2 | 23.9 | 17.2 | 100 | FTG | ---- | PE | 0.0 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | | 0.859 | TL | 3.00 | PV | |
| | Pipe: 3 | | | | | -24.8 | 1.049 | PL | 3.00 | PF | 0.8 |
| S3 | | 32.0 | 5.6 | 19.6 | 24.8 | 9.2 | 100 | FTG | ---- | PE | 0.0 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | | 0.271 | TL | 3.00 | PV | |
| | Pipe: 4 | | | | | -24.8 | 1.049 | PL | 1.80 | PF | 0.5 |
| S4 | | 32.0 | 5.6 | 19.7 | 24.8 | 9.2 | 100 | FTG | ---- | PE | 0.0 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | | 0.272 | TL | 1.80 | PV | |
| | Pipe: 5 | | | | | -22.8 | 1.049 | PL | 8.20 | PF | 1.9 |
| S5 | | 32.0 | 5.6 | 16.6 | 22.8 | 8.5 | 100 | FTG | ---- | PE | 0.0 |
| S6 | | 32.0 | 5.6 | 18.5 | 24.1 | | 0.233 | TL | 8.20 | PV | |
| | Pipe: 6 | | | | | -46.9 | 1.049 | PL | 1.80 | PF | 1.6 |
| S6 | | 32.0 | 5.6 | 18.5 | 24.1 | 17.4 | 100 | FTG | ---- | PE | 0.0 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.883 | TL | 1.80 | PV | |
| | Pipe: 7 | | | | | -19.5 | 1.049 | PL | 10.00 | PF | 1.7 |
| S7 | | 32.0 | 5.6 | 12.1 | 19.5 | 7.2 | 100 | FTG | ---- | PE | 0.0 |
| S8 | | 32.0 | 5.6 | 13.9 | 20.8 | | 0.174 | TL | 10.00 | PV | |
| | Pipe: 8 | | | | | -40.3 | 1.049 | PL | 8.20 | PF | 5.5 |
| S8 | | 32.0 | 5.6 | 13.9 | 20.8 | 15.0 | 100 | FTG | ---- | PE | 0.0 |
| S9 | | 32.0 | 5.6 | 19.3 | 24.6 | | 0.668 | TL | 8.20 | PV | |
| | Pipe: 9 | | | | | -65.0 | 1.380 | PL | 1.80 | PF | 0.8 |
| S9 | | 32.0 | 5.6 | 19.3 | 24.6 | 13.9 | 100 | FTG | ---- | PE | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.424 | TL | 1.80 | PV | |
| | Pipe: 10 | | | | | -22.9 | 1.049 | PL | 8.20 | PF | 1.9 |
| S10 | | 32.0 | 5.6 | 16.8 | 22.9 | 8.5 | 100 | FTG | ---- | PE | 0.0 |
| S11 | | 32.0 | 5.6 | 18.7 | 24.2 | | 0.235 | TL | 8.20 | PV | |
| | Pipe: 11 | | | | | -47.1 | 1.049 | PL | 1.80 | PF | 1.6 |
| S11 | | 32.0 | 5.6 | 18.7 | 24.2 | 17.5 | 100 | FTG | ---- | PE | 0.0 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.891 | TL | 1.80 | PV | |
| | Pipe: 12 | | | | | -23.9 | 1.049 | PL | 10.00 | PF | 2.5 |
| S12 | | 32.0 | 5.6 | 18.1 | 23.9 | 8.9 | 100 | FTG | ---- | PE | 0.0 |
| S13 | | 32.0 | 5.6 | 20.7 | 25.5 | | 0.253 | TL | 10.00 | PV | |
| | Pipe: 13 | | | | | -49.3 | 1.049 | PL | 2.20 | PF | 2.1 |
| S13 | | 32.0 | 5.6 | 20.7 | 25.5 | 18.3 | 100 | FTG | ---- | PE | 0.0 |
| 37 | | 32.0 | 0.0 | 22.8 | 0.0 | | 0.968 | TL | 2.20 | PV | |
| | Pipe: 14 | | | | | -25.6 | 1.049 | PL | 3.00 | PF | 0.9 |
| S14 | | 32.0 | 5.6 | 20.9 | 25.6 | 9.5 | 100 | FTG | ---- | PE | 0.0 |
| 38 | | 32.0 | 0.0 | 21.7 | 0.0 | | 0.288 | TL | 3.00 | PV | |

DATE: 4/28/20254.HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM WITHOUT BFP.SDF

JOB TITLE:

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | | |
|----------|----------|-------|------|-------|-------|-----------|----------|--------|--------|----|-----|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) | (FT) | SUM. | | |
| | | | | | | | FL/FT | | (PSI) | | |
| | Pipe: 15 | | | | | -25.2 | 1.049 | PL | 1.80 | PF | 0.5 |
| S15 | | 32.0 | 5.6 | 20.3 | 25.2 | 9.4 | 100 | FTG | ---- | PE | 0.0 |
| 20 | | 32.0 | 0.0 | 20.8 | 0.0 | | 0.281 | TL | 1.80 | PV | |
| | Pipe: 16 | | | | | 116.8 | 3.068 | PL | 10.00 | PF | 0.5 |
| 20 | | 32.0 | 0.0 | 20.8 | 0.0 | 5.1 | 100 | FTG | T | PE | 0.0 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.026 | TL | 20.71 | PV | |
| | Pipe: 17 | | | | | 69.6 | 3.068 | PL | 10.00 | PF | 0.2 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | 3.0 | 100 | FTG | T | PE | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.010 | TL | 20.71 | PV | |
| | Pipe: 18 | | | | | 4.6 | 3.068 | PL | 10.00 | PF | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | 0.2 | 100 | FTG | T | PE | 0.0 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.000 | TL | 20.71 | PV | |
| | Pipe: 19 | | | | | -42.3 | 3.068 | PL | 10.00 | PF | 0.1 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | 1.8 | 100 | FTG | T | PE | 0.0 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | | 0.004 | TL | 20.71 | PV | |
| | Pipe: 20 | | | | | -67.1 | 3.068 | PL | 3.00 | PF | 0.1 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | 2.9 | 100 | FTG | E | PE | 0.0 |
| 25 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.009 | TL | 8.00 | PV | |
| | Pipe: 21 | | | | | -67.1 | 3.068 | PL | 6.25 | PF | 0.2 |
| 25 | | 32.0 | 0.0 | 20.3 | 0.0 | 2.9 | 100 | FTG | T | PE | 0.0 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | | 0.009 | TL | 16.96 | PV | |
| | Pipe: 22 | | | | | -91.9 | 3.068 | PL | 10.00 | PF | 0.3 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | 4.0 | 100 | FTG | T | PE | 0.0 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | | 0.016 | TL | 20.71 | PV | |
| | Pipe: 23 | | | | | -138.1 | 3.068 | PL | 36.00 | PF | 1.4 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 28 | | 32.0 | 0.0 | 22.2 | 0.0 | | 0.035 | TL | 41.00 | PV | |
| | Pipe: 24 | | | | | -138.1 | 3.068 | PL | 12.50 | PF | 0.6 |
| 28 | | 32.0 | 0.0 | 22.2 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 29 | | 32.0 | 0.0 | 22.8 | 0.0 | | 0.035 | TL | 17.50 | PV | |
| | Pipe: 25 | | | | | -138.1 | 3.068 | PL | 17.22 | PF | 0.8 |
| 29 | | 32.0 | 0.0 | 22.8 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 30 | | 32.0 | 0.0 | 23.6 | 0.0 | | 0.035 | TL | 22.22 | PV | |
| | Pipe: 26 | | | | | -138.1 | 3.068 | PL | 12.50 | PF | 0.6 |
| 30 | | 32.0 | 0.0 | 23.6 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 31 | | 32.0 | 0.0 | 24.2 | 0.0 | | 0.035 | TL | 17.50 | PV | |
| | Pipe: 27 | | | | | -138.1 | 3.068 | PL | 35.00 | PF | 1.4 |
| 31 | | 32.0 | 0.0 | 24.2 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 32 | | 32.0 | 0.0 | 25.6 | 0.0 | | 0.035 | TL | 40.00 | PV | |
| | Pipe: 28 | | | | | -138.1 | 3.068 | PL | 26.50 | PF | 1.1 |
| 32 | | 32.0 | 0.0 | 25.6 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 33 | | 32.0 | 0.0 | 26.7 | 0.0 | | 0.035 | TL | 31.50 | PV | |
| | Pipe: 29 | | | | | -138.1 | 3.068 | PL | 18.30 | PF | 0.8 |
| 33 | | 32.0 | 0.0 | 26.7 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 34 | | 32.0 | 0.0 | 27.5 | 0.0 | | 0.035 | TL | 23.30 | PV | |


DATE: 4/28/20254.HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM WITHOUT BFP.SDF

JOB TITLE:

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | |
|----------|-------|-------|------|-------|-------|-----------|----------|--------|--------|----------|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) | (FT) | SUM. | |
| | | | | | | | FL/FT | | (PSI) | |
| Pipe: 30 | | | | | | -138.1 | 3.068 | PL | 18.85 | PF 0.8 |
| 34 | | 32.0 | 0.0 | 27.5 | 0.0 | 6.0 | 100 | FTG | E | PE 0.0 |
| 35 | | 32.0 | 0.0 | 28.3 | 0.0 | | 0.035 | TL | 23.85 | PV |
| Pipe: 31 | | | | | | -138.1 | 3.068 | PL | 5.10 | PF 0.6 |
| 35 | | 32.0 | 0.0 | 28.3 | 0.0 | 6.0 | 100 | FTG | T | PE 0.0 |
| 36 | | 32.0 | 0.0 | 28.9 | 0.0 | | 0.035 | TL | 15.81 | PV |
| Pipe: 32 | | | | | | 216.9 | 3.068 | PL | 64.77 | PF 6.1 |
| 36 | | 32.0 | 0.0 | 28.9 | 0.0 | 9.4 | 100 | FTG | T | PE 0.0 |
| 37 | | 32.0 | 0.0 | 22.8 | 0.0 | | 0.081 | TL | 75.48 | PV |
| Pipe: 33 | | | | | | 167.6 | 3.068 | PL | 11.00 | PF 1.0 |
| 37 | | 32.0 | 0.0 | 22.8 | 0.0 | 7.3 | 100 | FTG | 2E | PE 0.0 |
| 38 | | 32.0 | 0.0 | 21.7 | 0.0 | | 0.050 | TL | 20.99 | PV |
| Pipe: 34 | | | | | | 142.0 | 3.068 | PL | 6.25 | PF 0.4 |
| 38 | | 32.0 | 0.0 | 21.7 | 0.0 | 6.2 | 100 | FTG | E | PE 0.0 |
| 39 | | 32.0 | 0.0 | 21.3 | 0.0 | | 0.037 | TL | 11.25 | PV |
| Pipe: 35 | | | | | | 142.0 | 3.068 | PL | 3.00 | PF 0.5 |
| 39 | | 32.0 | 0.0 | 21.3 | 0.0 | 6.2 | 100 | FTG | T | PE 0.0 |
| 20 | | 32.0 | 0.0 | 20.8 | 0.0 | | 0.037 | TL | 13.71 | PV |
| Pipe: 36 | | | | | | -355.0 | 3.068 | PL | 2.50 | PF 1.5 |
| 36 | | 32.0 | 0.0 | 28.9 | 0.0 | 15.4 | 100 | FTG | E | PE 0.0 |
| 40 | | 32.0 | 0.0 | 30.4 | 0.0 | | 0.200 | TL | 7.50 | PV |
| Pipe: 37 | | | | | | 355.0 | 3.068 | PL | 30.00 | PF 10.2 |
| 41 | | 2.0 | 0.0 | 53.5 | 0.0 | 15.4 | 100 | FTG | TGD | PE -13.0 |
| 40 | | 32.0 | 0.0 | 30.4 | 0.0 | | 0.200 | TL | 50.70 | PV |
| Pipe: 38 | | | | | | -355.0 | 7.981 | PL | 6.00 | PF 0.0 |
| 41 | | 2.0 | 0.0 | 53.5 | 0.0 | 2.3 | 120 | FTG | ---- | PE 0.0 |
| 42 | | 2.0 | 0.0 | 53.6 | 0.0 | | 0.001 | TL | 6.00 | PV |
| Pipe: 39 | | | | | | -355.0 | 7.981 | PL | 2.00 | PF 0.0 |
| 42 | | 2.0 | 0.0 | 53.6 | 0.0 | 2.3 | 120 | FTG | E | PE 0.0 |
| 43 | | 2.0 | 0.0 | 53.6 | 0.0 | | 0.001 | TL | 20.00 | PV |
| Pipe: 40 | | | | | | -355.0 | 7.981 | PL | 2.00 | PF 0.0 |
| 43 | | 2.0 | 0.0 | 53.6 | 0.0 | 2.3 | 120 | FTG | E | PE 0.9 |
| 44 | | 0.0 | 0.0 | 54.5 | 0.0 | | 0.001 | TL | 20.00 | PV |
| Pipe: 41 | | | | | | -355.0 | 7.981 | PL | 7.00 | PF 0.0 |
| 44 | | 0.0 | 0.0 | 54.5 | 0.0 | 2.3 | 120 | FTG | E | PE 0.0 |
| 45 | | 0.0 | 0.0 | 54.5 | 0.0 | | 0.001 | TL | 25.00 | PV |
| Pipe: 42 | | | | | | -355.0 | 7.981 | PL | 5.00 | PF 0.0 |
| 45 | | 0.0 | 0.0 | 54.5 | 0.0 | 2.3 | 120 | FTG | E | PE 2.2 |
| 46 | | -5.0 | 0.0 | 56.7 | 0.0 | | 0.001 | TL | 23.00 | PV |
| Pipe: 43 | | | | | | -355.0 | 7.981 | PL | 82.00 | PF 0.1 |
| 46 | | -5.0 | 0.0 | 56.7 | 0.0 | 2.3 | 120 | FTG | ---- | PE 0.0 |
| SRC | | -5.0 | SRCE | 56.8 | (N/A) | | 0.001 | TL | 82.00 | PV |

WATER SUPPLY ANALYSIS

Static: 60.00 psi Resid: 55.00 psi Flow: 1160.0 gpm



DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF

JOB TITLE:

WATER SUPPLY DATA

| SOURCE NODE TAG | STATIC PRESS. (PSI) | RESID. PRESS. (PSI) | FLOW @ (GPM) | AVAIL. PRESS. (PSI) | TOTAL @ DEMAND (GPM) | REQ'D PRESS. (PSI) |
|-----------------------|---------------------------|---------------------------|--------------------|---------------------------|-------------------------------|--------------------------|
| SRC | 60.0 | 55.0 | 1160.0 | 59.4 | 355.0 | 61.8 |

AGGREGATE FLOW ANALYSIS:

| | |
|--|-----------|
| TOTAL FLOW AT SOURCE | 355.0 GPM |
| TOTAL HOSE STREAM ALLOWANCE AT SOURCE | 0.0 GPM |
| OTHER HOSE STREAM ALLOWANCES | 0.0 GPM |
| TOTAL DISCHARGE FROM ACTIVE SPRINKLERS | 355.0 GPM |

NODE ANALYSIS DATA

| NODE TAG | ELEVATION (FT) | NODE TYPE | PRESSURE (PSI) | DISCHARGE (GPM) |
|----------|-------------------|-----------|-------------------|--------------------|
| S1 | 32.0 | K= 5.60 | 15.9 | 22.4 |
| S2 | 32.0 | K= 5.60 | 18.2 | 23.9 |
| S3 | 32.0 | K= 5.60 | 19.6 | 24.8 |
| S4 | 32.0 | K= 5.60 | 19.7 | 24.8 |
| S5 | 32.0 | K= 5.60 | 16.6 | 22.8 |
| S6 | 32.0 | K= 5.60 | 18.5 | 24.1 |
| S7 | 32.0 | K= 5.60 | 12.1 | 19.5 |
| S8 | 32.0 | K= 5.60 | 13.9 | 20.8 |
| S9 | 32.0 | K= 5.60 | 19.3 | 24.6 |
| S10 | 32.0 | K= 5.60 | 16.8 | 22.9 |
| S11 | 32.0 | K= 5.60 | 18.7 | 24.2 |
| S12 | 32.0 | K= 5.60 | 18.1 | 23.9 |
| S13 | 32.0 | K= 5.60 | 20.7 | 25.5 |
| S14 | 32.0 | K= 5.60 | 20.9 | 25.6 |
| S15 | 32.0 | K= 5.60 | 20.3 | 25.2 |
| 20 | 32.0 | - - - - | 20.8 | - - - |
| 21 | 32.0 | - - - - | 20.3 | - - - |
| 22 | 32.0 | - - - - | 20.1 | - - - |
| 23 | 32.0 | - - - - | 20.1 | - - - |
| 24 | 32.0 | - - - - | 20.2 | - - - |
| 25 | 32.0 | - - - - | 20.3 | - - - |
| 26 | 32.0 | - - - - | 20.4 | - - - |
| 27 | 32.0 | - - - - | 20.7 | - - - |
| 28 | 32.0 | - - - - | 22.2 | - - - |
| 29 | 32.0 | - - - - | 22.8 | - - - |
| 30 | 32.0 | - - - - | 23.6 | - - - |
| 31 | 32.0 | - - - - | 24.2 | - - - |
| 32 | 32.0 | - - - - | 25.6 | - - - |
| 33 | 32.0 | - - - - | 26.7 | - - - |
| 34 | 32.0 | - - - - | 27.5 | - - - |
| 35 | 32.0 | - - - - | 28.3 | - - - |
| 36 | 32.0 | - - - - | 28.9 | - - - |
| 37 | 32.0 | - - - - | 22.8 | - - - |
| 38 | 32.0 | - - - - | 21.7 | - - - |
| 39 | 32.0 | - - - - | 21.3 | - - - |
| 40 | 32.0 | - - - - | 30.4 | - - - |
| 41 | 2.0 | - - - - | 53.5 | - - - |
| 42 | 2.0 | - - - - | 53.6 | - - - |
| 43 | 2.0 | - - - - | 53.6 | - - - |
| 44 | 0.0 | - - - - | 54.5 | - - - |
| BFP-OUT | 0.0 | - - - - | 54.5 | - - - |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF

JOB TITLE:

NODE ANALYSIS DATA

| NODE TAG | ELEVATION (FT) | NODE TYPE | PRESSURE (PSI) | DISCHARGE (GPM) |
|----------|-------------------|-----------|-------------------|--------------------|
| BFP-IN | 0.0 | - - - - | 59.5 | - - - |
| 45 | 0.0 | - - - - | 59.5 | - - - |
| 46 | -5.0 | - - - - | 61.7 | - - - |
| SRC | -5.0 | SOURCE | 61.8 | 355.0 |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

PIPE DATA

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | |
|----------|----------|-------|------|-------|-------|-----------|-----------------|--------|--------|-----|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) FL/FT | (FT) | SUM. | |
| | | | | | | | | | (PSI) | |
| | Pipe: 1 | | | | | -22.4 | 1.049 PL | 10.00 | PF | 2.2 |
| S1 | | 32.0 | 5.6 | 15.9 | 22.4 | 8.3 | 100 FTG | ---- | PE | 0.0 |
| S2 | | 32.0 | 5.6 | 18.2 | 23.9 | | 0.224 TL | 10.00 | PV | |
| | Pipe: 2 | | | | | -46.2 | 1.049 PL | 3.00 | PF | 2.6 |
| S2 | | 32.0 | 5.6 | 18.2 | 23.9 | 17.2 | 100 FTG | ---- | PE | 0.0 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | | 0.859 TL | 3.00 | PV | |
| | Pipe: 3 | | | | | -24.8 | 1.049 PL | 3.00 | PF | 0.8 |
| S3 | | 32.0 | 5.6 | 19.6 | 24.8 | 9.2 | 100 FTG | ---- | PE | 0.0 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | | 0.271 TL | 3.00 | PV | |
| | Pipe: 4 | | | | | -24.8 | 1.049 PL | 1.80 | PF | 0.5 |
| S4 | | 32.0 | 5.6 | 19.7 | 24.8 | 9.2 | 100 FTG | ---- | PE | 0.0 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | | 0.272 TL | 1.80 | PV | |
| | Pipe: 5 | | | | | -22.8 | 1.049 PL | 8.20 | PF | 1.9 |
| S5 | | 32.0 | 5.6 | 16.6 | 22.8 | 8.5 | 100 FTG | ---- | PE | 0.0 |
| S6 | | 32.0 | 5.6 | 18.5 | 24.1 | | 0.233 TL | 8.20 | PV | |
| | Pipe: 6 | | | | | -46.9 | 1.049 PL | 1.80 | PF | 1.6 |
| S6 | | 32.0 | 5.6 | 18.5 | 24.1 | 17.4 | 100 FTG | ---- | PE | 0.0 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.883 TL | 1.80 | PV | |
| | Pipe: 7 | | | | | -19.5 | 1.049 PL | 10.00 | PF | 1.7 |
| S7 | | 32.0 | 5.6 | 12.1 | 19.5 | 7.2 | 100 FTG | ---- | PE | 0.0 |
| S8 | | 32.0 | 5.6 | 13.9 | 20.8 | | 0.174 TL | 10.00 | PV | |
| | Pipe: 8 | | | | | -40.3 | 1.049 PL | 8.20 | PF | 5.5 |
| S8 | | 32.0 | 5.6 | 13.9 | 20.8 | 15.0 | 100 FTG | ---- | PE | 0.0 |
| S9 | | 32.0 | 5.6 | 19.3 | 24.6 | | 0.668 TL | 8.20 | PV | |
| | Pipe: 9 | | | | | -65.0 | 1.380 PL | 1.80 | PF | 0.8 |
| S9 | | 32.0 | 5.6 | 19.3 | 24.6 | 13.9 | 100 FTG | ---- | PE | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.424 TL | 1.80 | PV | |
| | Pipe: 10 | | | | | -22.9 | 1.049 PL | 8.20 | PF | 1.9 |
| S10 | | 32.0 | 5.6 | 16.8 | 22.9 | 8.5 | 100 FTG | ---- | PE | 0.0 |
| S11 | | 32.0 | 5.6 | 18.7 | 24.2 | | 0.235 TL | 8.20 | PV | |
| | Pipe: 11 | | | | | -47.1 | 1.049 PL | 1.80 | PF | 1.6 |
| S11 | | 32.0 | 5.6 | 18.7 | 24.2 | 17.5 | 100 FTG | ---- | PE | 0.0 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.891 TL | 1.80 | PV | |
| | Pipe: 12 | | | | | -23.9 | 1.049 PL | 10.00 | PF | 2.5 |
| S12 | | 32.0 | 5.6 | 18.1 | 23.9 | 8.9 | 100 FTG | ---- | PE | 0.0 |
| S13 | | 32.0 | 5.6 | 20.7 | 25.5 | | 0.253 TL | 10.00 | PV | |
| | Pipe: 13 | | | | | -49.3 | 1.049 PL | 2.20 | PF | 2.1 |
| S13 | | 32.0 | 5.6 | 20.7 | 25.5 | 18.3 | 100 FTG | ---- | PE | 0.0 |
| 37 | | 32.0 | 0.0 | 22.8 | 0.0 | | 0.968 TL | 2.20 | PV | |
| | Pipe: 14 | | | | | -25.6 | 1.049 PL | 3.00 | PF | 0.9 |
| S14 | | 32.0 | 5.6 | 20.9 | 25.6 | 9.5 | 100 FTG | ---- | PE | 0.0 |
| 38 | | 32.0 | 0.0 | 21.7 | 0.0 | | 0.288 TL | 3.00 | PV | |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | | |
|----------|----------|-------|------|-------|-------|-----------|----------|--------|--------|----|-----|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) | (FT) | SUM. | | |
| | | | | | | | FL/FT | | (PSI) | | |
| | Pipe: 15 | | | | | -25.2 | 1.049 | PL | 1.80 | PF | 0.5 |
| S15 | | 32.0 | 5.6 | 20.3 | 25.2 | 9.4 | 100 | FTG | ---- | PE | 0.0 |
| 20 | | 32.0 | 0.0 | 20.8 | 0.0 | | 0.281 | TL | 1.80 | PV | |
| | Pipe: 16 | | | | | 116.8 | 3.068 | PL | 10.00 | PF | 0.5 |
| 20 | | 32.0 | 0.0 | 20.8 | 0.0 | 5.1 | 100 | FTG | T | PE | 0.0 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.026 | TL | 20.71 | PV | |
| | Pipe: 17 | | | | | 69.6 | 3.068 | PL | 10.00 | PF | 0.2 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | 3.0 | 100 | FTG | T | PE | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.010 | TL | 20.71 | PV | |
| | Pipe: 18 | | | | | 4.6 | 3.068 | PL | 10.00 | PF | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | 0.2 | 100 | FTG | T | PE | 0.0 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.000 | TL | 20.71 | PV | |
| | Pipe: 19 | | | | | -42.3 | 3.068 | PL | 10.00 | PF | 0.1 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | 1.8 | 100 | FTG | T | PE | 0.0 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | | 0.004 | TL | 20.71 | PV | |
| | Pipe: 20 | | | | | -67.1 | 3.068 | PL | 3.00 | PF | 0.1 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | 2.9 | 100 | FTG | E | PE | 0.0 |
| 25 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.009 | TL | 8.00 | PV | |
| | Pipe: 21 | | | | | -67.1 | 3.068 | PL | 6.25 | PF | 0.2 |
| 25 | | 32.0 | 0.0 | 20.3 | 0.0 | 2.9 | 100 | FTG | T | PE | 0.0 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | | 0.009 | TL | 16.96 | PV | |
| | Pipe: 22 | | | | | -91.9 | 3.068 | PL | 10.00 | PF | 0.3 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | 4.0 | 100 | FTG | T | PE | 0.0 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | | 0.016 | TL | 20.71 | PV | |
| | Pipe: 23 | | | | | -138.1 | 3.068 | PL | 36.00 | PF | 1.4 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 28 | | 32.0 | 0.0 | 22.2 | 0.0 | | 0.035 | TL | 41.00 | PV | |
| | Pipe: 24 | | | | | -138.1 | 3.068 | PL | 12.50 | PF | 0.6 |
| 28 | | 32.0 | 0.0 | 22.2 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 29 | | 32.0 | 0.0 | 22.8 | 0.0 | | 0.035 | TL | 17.50 | PV | |
| | Pipe: 25 | | | | | -138.1 | 3.068 | PL | 17.22 | PF | 0.8 |
| 29 | | 32.0 | 0.0 | 22.8 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 30 | | 32.0 | 0.0 | 23.6 | 0.0 | | 0.035 | TL | 22.22 | PV | |
| | Pipe: 26 | | | | | -138.1 | 3.068 | PL | 12.50 | PF | 0.6 |
| 30 | | 32.0 | 0.0 | 23.6 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 31 | | 32.0 | 0.0 | 24.2 | 0.0 | | 0.035 | TL | 17.50 | PV | |
| | Pipe: 27 | | | | | -138.1 | 3.068 | PL | 35.00 | PF | 1.4 |
| 31 | | 32.0 | 0.0 | 24.2 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 32 | | 32.0 | 0.0 | 25.6 | 0.0 | | 0.035 | TL | 40.00 | PV | |
| | Pipe: 28 | | | | | -138.1 | 3.068 | PL | 26.50 | PF | 1.1 |
| 32 | | 32.0 | 0.0 | 25.6 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 33 | | 32.0 | 0.0 | 26.7 | 0.0 | | 0.035 | TL | 31.50 | PV | |
| | Pipe: 29 | | | | | -138.1 | 3.068 | PL | 18.30 | PF | 0.8 |
| 33 | | 32.0 | 0.0 | 26.7 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 34 | | 32.0 | 0.0 | 27.5 | 0.0 | | 0.035 | TL | 23.30 | PV | |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | | |
|----------|------|-------|-------|-------|-----------|----------------------------|----------|--------|--------|-------|------|
| NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) | FL/FT | (FT) | SUM. | | |
| | | | | | | | | | (PSI) | | |
| Pipe: 30 | | | | | | -138.1 | 3.068 | PL | 18.85 | PF | 0.8 |
| 34 | 32.0 | 0.0 | 27.5 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 | |
| 35 | 32.0 | 0.0 | 28.3 | 0.0 | | 0.035 | TL | 23.85 | PV | | |
| Pipe: 31 | | | | | | -138.1 | 3.068 | PL | 5.10 | PF | 0.6 |
| 35 | 32.0 | 0.0 | 28.3 | 0.0 | 6.0 | 100 | FTG | T | PE | 0.0 | |
| 36 | 32.0 | 0.0 | 28.9 | 0.0 | | 0.035 | TL | 15.81 | PV | | |
| Pipe: 32 | | | | | | 216.9 | 3.068 | PL | 64.77 | PF | 6.1 |
| 36 | 32.0 | 0.0 | 28.9 | 0.0 | 9.4 | 100 | FTG | T | PE | 0.0 | |
| 37 | 32.0 | 0.0 | 22.8 | 0.0 | | 0.081 | TL | 75.48 | PV | | |
| Pipe: 33 | | | | | | 167.6 | 3.068 | PL | 11.00 | PF | 1.0 |
| 37 | 32.0 | 0.0 | 22.8 | 0.0 | 7.3 | 100 | FTG | 2E | PE | 0.0 | |
| 38 | 32.0 | 0.0 | 21.7 | 0.0 | | 0.050 | TL | 20.99 | PV | | |
| Pipe: 34 | | | | | | 142.0 | 3.068 | PL | 6.25 | PF | 0.4 |
| 38 | 32.0 | 0.0 | 21.7 | 0.0 | 6.2 | 100 | FTG | E | PE | 0.0 | |
| 39 | 32.0 | 0.0 | 21.3 | 0.0 | | 0.037 | TL | 11.25 | PV | | |
| Pipe: 35 | | | | | | 142.0 | 3.068 | PL | 3.00 | PF | 0.5 |
| 39 | 32.0 | 0.0 | 21.3 | 0.0 | 6.2 | 100 | FTG | T | PE | 0.0 | |
| 20 | 32.0 | 0.0 | 20.8 | 0.0 | | 0.037 | TL | 13.71 | PV | | |
| Pipe: 36 | | | | | | -355.0 | 3.068 | PL | 2.50 | PF | 1.5 |
| 36 | 32.0 | 0.0 | 28.9 | 0.0 | 15.4 | 100 | FTG | E | PE | 0.0 | |
| 40 | 32.0 | 0.0 | 30.4 | 0.0 | | 0.200 | TL | 7.50 | PV | | |
| Pipe: 37 | | | | | | 355.0 | 3.068 | PL | 30.00 | PF | 10.2 |
| 41 | 2.0 | 0.0 | 53.5 | 0.0 | 15.4 | 100 | FTG | TGD | PE | -13.0 | |
| 40 | 32.0 | 0.0 | 30.4 | 0.0 | | 0.200 | TL | 50.70 | PV | | |
| Pipe: 38 | | | | | | -355.0 | 7.981 | PL | 6.00 | PF | 0.0 |
| 41 | 2.0 | 0.0 | 53.5 | 0.0 | 2.3 | 120 | FTG | ---- | PE | 0.0 | |
| 42 | 2.0 | 0.0 | 53.6 | 0.0 | | 0.001 | TL | 6.00 | PV | | |
| Pipe: 39 | | | | | | -355.0 | 7.981 | PL | 2.00 | PF | 0.0 |
| 42 | 2.0 | 0.0 | 53.6 | 0.0 | 2.3 | 120 | FTG | E | PE | 0.0 | |
| 43 | 2.0 | 0.0 | 53.6 | 0.0 | | 0.001 | TL | 20.00 | PV | | |
| Pipe: 40 | | | | | | -355.0 | 7.981 | PL | 2.00 | PF | 0.0 |
| 43 | 2.0 | 0.0 | 53.6 | 0.0 | 2.3 | 120 | FTG | E | PE | 0.9 | |
| 44 | 0.0 | 0.0 | 54.5 | 0.0 | | 0.001 | TL | 20.00 | PV | | |
| Pipe: 41 | | | | | | -355.0 | 7.981 | PL | 2.00 | PF | 0.0 |
| 44 | 0.0 | 0.0 | 54.5 | 0.0 | 2.3 | 120 | FTG | ---- | PE | 0.0 | |
| BFP-OUT | 0.0 | 0.0 | 54.5 | 0.0 | | 0.001 | TL | 2.00 | PV | | |
| Pipe: 42 | | | | | | FIXED PRESSURE LOSS DEVICE | | | | | |
| BFP-IN | 0.0 | 0.0 | 59.5 | 0.0 | | 5.0 psi, 355.0 gpm | | | | | |
| BFP-OUT | 0.0 | 0.0 | 54.5 | 0.0 | | | | | | | |
| Pipe: 43 | | | | | | -355.0 | 7.981 | PL | 4.00 | PF | 0.0 |
| BFP-IN | 0.0 | 0.0 | 59.5 | 0.0 | 2.3 | 120 | FTG | E | PE | 0.0 | |
| 45 | 0.0 | 0.0 | 59.5 | 0.0 | | 0.001 | TL | 22.00 | PV | | |
| Pipe: 44 | | | | | | -355.0 | 7.981 | PL | 5.00 | PF | 0.0 |
| 45 | 0.0 | 0.0 | 59.5 | 0.0 | 2.3 | 120 | FTG | E | PE | 2.2 | |
| 46 | -5.0 | 0.0 | 61.7 | 0.0 | | 0.001 | TL | 23.00 | PV | | |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

| PIPE TAG | Q (GPM) | DIA (IN) | LENGTH | PRESS. |
|--|---------|----------|--------|--------|
| END ELEV. NOZ. PT DISC. VEL (FPS) HW (C) (FT) SUM. | | | | |
| NODES (FT) (K) (PSI) (GPM) FL/FT (PSI) | | | | |
| Pipe: 45 | -355.0 | 7.981 PL | 82.00 | PF 0.1 |
| 46 | 2.3 | 120 FTG | ---- | PE 0.0 |
| SRC | (N/A) | 0.001 TL | 82.00 | PV |

NOTES (HASS):

- (1) Calculations were performed by the HASS computer program in accordance with NFPA (2020) under license no. 65699794 granted by HRS Systems, Inc. 208 Southside Square Petersburg, TN 37144 (931) 659-9760
- (2) The system has been calculated to provide an average imbalance at each node of 0.004 gpm and a maximum imbalance at any node of 0.171 gpm.
- (3) Total pressure at each node is used in balancing the system. Maximum water velocity is 18.3 ft/sec at pipe 13.
- (4) Items listed in bold print on the cover sheet are automatically transferred from the calculation report.
- (5) Available pressure at source node SRC under full flow conditions is 59.47 psi with a flow of 344.24 gpm.
- (6) PIPE FITTINGS TABLE


HASS Pipe Table Name: standard

PAGE: A MATERIAL: S40 HWC: 120

| Diameter (in) | Equivalent Fitting Lengths in Feet | | | | | | | | | |
|---------------|------------------------------------|-------|-------|-------|----------|----------|----------|----------|---------|-------|
| | E Ell | T Tee | L Lng | C Ell | B ChkVlv | G BfyVlv | A GatVlv | D AlmChk | N DPVlv | T Tee |
| 1.049 | 2.00 | 5.00 | 2.00 | 5.00 | 6.00 | 1.00 | 10.00 | 2.00 | 5.00 | |
| 1.380 | 3.00 | 6.00 | 2.00 | 7.00 | 6.00 | 1.00 | 10.00 | 10.00 | 6.00 | |
| 3.068 | 7.00 | 15.00 | 5.00 | 16.00 | 10.00 | 1.00 | 13.00 | 13.00 | 15.00 | |
| 7.981 | 18.00 | 35.00 | 13.00 | 45.00 | 12.00 | 4.00 | 31.00 | 31.00 | 35.00 | |

WATER SUPPLY ANALYSIS

Static: 60.00 psi Resid: 55.00 psi Flow: 1160.0 gpm




Note: (1) Dashed Lines indicate extrapolated values from Test Results

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF

JOB TITLE:

WATER SUPPLY CURVE



DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

Dry System with modified 4" riser

WATER SUPPLY DATA

| SOURCE NODE TAG | STATIC PRESS. (PSI) | RESID. PRESS. (PSI) | FLOW @ (GPM) | AVAIL. PRESS. (PSI) | TOTAL @ DEMAND (GPM) | REQ'D PRESS. (PSI) |
|-----------------------|---------------------------|---------------------------|--------------------|---------------------------|-------------------------------|--------------------------|
| SRC | 60.0 | 55.0 | 1160.0 | 59.4 | 355.0 | 53.9 |

AGGREGATE FLOW ANALYSIS:

| | |
|--|-----------|
| TOTAL FLOW AT SOURCE | 355.0 GPM |
| TOTAL HOSE STREAM ALLOWANCE AT SOURCE | 0.0 GPM |
| OTHER HOSE STREAM ALLOWANCES | 0.0 GPM |
| TOTAL DISCHARGE FROM ACTIVE SPRINKLERS | 355.0 GPM |

NODE ANALYSIS DATA

| NODE TAG | ELEVATION (FT) | NODE TYPE | PRESSURE (PSI) | DISCHARGE (GPM) |
|----------|-------------------|-----------|-------------------|--------------------|
| S1 | 32.0 | K= 5.60 | 15.9 | 22.4 |
| S2 | 32.0 | K= 5.60 | 18.2 | 23.9 |
| S3 | 32.0 | K= 5.60 | 19.6 | 24.8 |
| S4 | 32.0 | K= 5.60 | 19.7 | 24.8 |
| S5 | 32.0 | K= 5.60 | 16.6 | 22.8 |
| S6 | 32.0 | K= 5.60 | 18.5 | 24.1 |
| S7 | 32.0 | K= 5.60 | 12.1 | 19.5 |
| S8 | 32.0 | K= 5.60 | 13.9 | 20.8 |
| S9 | 32.0 | K= 5.60 | 19.3 | 24.6 |
| S10 | 32.0 | K= 5.60 | 16.8 | 22.9 |
| S11 | 32.0 | K= 5.60 | 18.7 | 24.2 |
| S12 | 32.0 | K= 5.60 | 18.1 | 23.9 |
| S13 | 32.0 | K= 5.60 | 20.7 | 25.5 |
| S14 | 32.0 | K= 5.60 | 20.9 | 25.6 |
| S15 | 32.0 | K= 5.60 | 20.3 | 25.2 |
| 20 | 32.0 | - - - - | 20.8 | - - - |
| 21 | 32.0 | - - - - | 20.3 | - - - |
| 22 | 32.0 | - - - - | 20.1 | - - - |
| 23 | 32.0 | - - - - | 20.1 | - - - |
| 24 | 32.0 | - - - - | 20.2 | - - - |
| 25 | 32.0 | - - - - | 20.3 | - - - |
| 26 | 32.0 | - - - - | 20.4 | - - - |
| 27 | 32.0 | - - - - | 20.7 | - - - |
| 28 | 32.0 | - - - - | 22.2 | - - - |
| 29 | 32.0 | - - - - | 22.8 | - - - |
| 30 | 32.0 | - - - - | 23.6 | - - - |
| 31 | 32.0 | - - - - | 24.2 | - - - |
| 32 | 32.0 | - - - - | 25.6 | - - - |
| 33 | 32.0 | - - - - | 26.7 | - - - |
| 34 | 32.0 | - - - - | 27.5 | - - - |
| 35 | 32.0 | - - - - | 28.3 | - - - |
| 36 | 32.0 | - - - - | 28.9 | - - - |
| 37 | 32.0 | - - - - | 22.8 | - - - |
| 38 | 32.0 | - - - - | 21.7 | - - - |
| 39 | 32.0 | - - - - | 21.3 | - - - |
| 40 | 32.0 | - - - - | 29.4 | - - - |
| 41 | 2.0 | - - - - | 45.6 | - - - |
| 42 | 2.0 | - - - - | 45.6 | - - - |
| 43 | 2.0 | - - - - | 45.6 | - - - |
| 44 | 0.0 | - - - - | 46.5 | - - - |
| BFP-OUT | 0.0 | - - - - | 46.5 | - - - |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF

JOB TITLE:

NODE ANALYSIS DATA

| NODE TAG | ELEVATION (FT) | NODE TYPE | PRESSURE (PSI) | DISCHARGE (GPM) |
|----------|-------------------|-----------|-------------------|--------------------|
| BFP-IN | 0.0 | - - - - | 51.5 | - - - |
| 45 | 0.0 | - - - - | 51.6 | - - - |
| 46 | -5.0 | - - - - | 53.8 | - - - |
| SRC | -5.0 | SOURCE | 53.9 | 355.0 |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

PIPE DATA

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | |
|----------|----------|-------|------|-------|-------|-----------|-----------------|--------|--------|-----|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) FL/FT | (FT) | SUM. | |
| | | | | | | | | | (PSI) | |
| | Pipe: 1 | | | | | -22.4 | 1.049 PL | 10.00 | PF | 2.2 |
| S1 | | 32.0 | 5.6 | 15.9 | 22.4 | 8.3 | 100 FTG | ---- | PE | 0.0 |
| S2 | | 32.0 | 5.6 | 18.2 | 23.9 | | 0.224 TL | 10.00 | PV | |
| | Pipe: 2 | | | | | -46.2 | 1.049 PL | 3.00 | PF | 2.6 |
| S2 | | 32.0 | 5.6 | 18.2 | 23.9 | 17.2 | 100 FTG | ---- | PE | 0.0 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | | 0.859 TL | 3.00 | PV | |
| | Pipe: 3 | | | | | -24.8 | 1.049 PL | 3.00 | PF | 0.8 |
| S3 | | 32.0 | 5.6 | 19.6 | 24.8 | 9.2 | 100 FTG | ---- | PE | 0.0 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | | 0.271 TL | 3.00 | PV | |
| | Pipe: 4 | | | | | -24.8 | 1.049 PL | 1.80 | PF | 0.5 |
| S4 | | 32.0 | 5.6 | 19.7 | 24.8 | 9.2 | 100 FTG | ---- | PE | 0.0 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | | 0.272 TL | 1.80 | PV | |
| | Pipe: 5 | | | | | -22.8 | 1.049 PL | 8.20 | PF | 1.9 |
| S5 | | 32.0 | 5.6 | 16.6 | 22.8 | 8.5 | 100 FTG | ---- | PE | 0.0 |
| S6 | | 32.0 | 5.6 | 18.5 | 24.1 | | 0.233 TL | 8.20 | PV | |
| | Pipe: 6 | | | | | -46.9 | 1.049 PL | 1.80 | PF | 1.6 |
| S6 | | 32.0 | 5.6 | 18.5 | 24.1 | 17.4 | 100 FTG | ---- | PE | 0.0 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.883 TL | 1.80 | PV | |
| | Pipe: 7 | | | | | -19.5 | 1.049 PL | 10.00 | PF | 1.7 |
| S7 | | 32.0 | 5.6 | 12.1 | 19.5 | 7.2 | 100 FTG | ---- | PE | 0.0 |
| S8 | | 32.0 | 5.6 | 13.9 | 20.8 | | 0.174 TL | 10.00 | PV | |
| | Pipe: 8 | | | | | -40.3 | 1.049 PL | 8.20 | PF | 5.5 |
| S8 | | 32.0 | 5.6 | 13.9 | 20.8 | 15.0 | 100 FTG | ---- | PE | 0.0 |
| S9 | | 32.0 | 5.6 | 19.3 | 24.6 | | 0.668 TL | 8.20 | PV | |
| | Pipe: 9 | | | | | -65.0 | 1.380 PL | 1.80 | PF | 0.8 |
| S9 | | 32.0 | 5.6 | 19.3 | 24.6 | 13.9 | 100 FTG | ---- | PE | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.424 TL | 1.80 | PV | |
| | Pipe: 10 | | | | | -22.9 | 1.049 PL | 8.20 | PF | 1.9 |
| S10 | | 32.0 | 5.6 | 16.8 | 22.9 | 8.5 | 100 FTG | ---- | PE | 0.0 |
| S11 | | 32.0 | 5.6 | 18.7 | 24.2 | | 0.235 TL | 8.20 | PV | |
| | Pipe: 11 | | | | | -47.1 | 1.049 PL | 1.80 | PF | 1.6 |
| S11 | | 32.0 | 5.6 | 18.7 | 24.2 | 17.5 | 100 FTG | ---- | PE | 0.0 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.891 TL | 1.80 | PV | |
| | Pipe: 12 | | | | | -23.9 | 1.049 PL | 10.00 | PF | 2.5 |
| S12 | | 32.0 | 5.6 | 18.1 | 23.9 | 8.9 | 100 FTG | ---- | PE | 0.0 |
| S13 | | 32.0 | 5.6 | 20.7 | 25.5 | | 0.253 TL | 10.00 | PV | |
| | Pipe: 13 | | | | | -49.3 | 1.049 PL | 2.20 | PF | 2.1 |
| S13 | | 32.0 | 5.6 | 20.7 | 25.5 | 18.3 | 100 FTG | ---- | PE | 0.0 |
| 37 | | 32.0 | 0.0 | 22.8 | 0.0 | | 0.968 TL | 2.20 | PV | |
| | Pipe: 14 | | | | | -25.6 | 1.049 PL | 3.00 | PF | 0.9 |
| S14 | | 32.0 | 5.6 | 20.9 | 25.6 | 9.5 | 100 FTG | ---- | PE | 0.0 |
| 38 | | 32.0 | 0.0 | 21.7 | 0.0 | | 0.288 TL | 3.00 | PV | |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | | |
|----------|----------|-------|------|-------|-------|-----------|----------|--------|--------|----|-----|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) | (FT) | SUM. | | |
| | | | | | | | FL/FT | | (PSI) | | |
| | Pipe: 15 | | | | | -25.2 | 1.049 | PL | 1.80 | PF | 0.5 |
| S15 | | 32.0 | 5.6 | 20.3 | 25.2 | 9.4 | 100 | FTG | ---- | PE | 0.0 |
| 20 | | 32.0 | 0.0 | 20.8 | 0.0 | | 0.281 | TL | 1.80 | PV | |
| | Pipe: 16 | | | | | 116.8 | 3.068 | PL | 10.00 | PF | 0.5 |
| 20 | | 32.0 | 0.0 | 20.8 | 0.0 | 5.1 | 100 | FTG | T | PE | 0.0 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.026 | TL | 20.71 | PV | |
| | Pipe: 17 | | | | | 69.6 | 3.068 | PL | 10.00 | PF | 0.2 |
| 21 | | 32.0 | 0.0 | 20.3 | 0.0 | 3.0 | 100 | FTG | T | PE | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.010 | TL | 20.71 | PV | |
| | Pipe: 18 | | | | | 4.6 | 3.068 | PL | 10.00 | PF | 0.0 |
| 22 | | 32.0 | 0.0 | 20.1 | 0.0 | 0.2 | 100 | FTG | T | PE | 0.0 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | | 0.000 | TL | 20.71 | PV | |
| | Pipe: 19 | | | | | -42.3 | 3.068 | PL | 10.00 | PF | 0.1 |
| 23 | | 32.0 | 0.0 | 20.1 | 0.0 | 1.8 | 100 | FTG | T | PE | 0.0 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | | 0.004 | TL | 20.71 | PV | |
| | Pipe: 20 | | | | | -67.1 | 3.068 | PL | 3.00 | PF | 0.1 |
| 24 | | 32.0 | 0.0 | 20.2 | 0.0 | 2.9 | 100 | FTG | E | PE | 0.0 |
| 25 | | 32.0 | 0.0 | 20.3 | 0.0 | | 0.009 | TL | 8.00 | PV | |
| | Pipe: 21 | | | | | -67.1 | 3.068 | PL | 6.25 | PF | 0.2 |
| 25 | | 32.0 | 0.0 | 20.3 | 0.0 | 2.9 | 100 | FTG | T | PE | 0.0 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | | 0.009 | TL | 16.96 | PV | |
| | Pipe: 22 | | | | | -91.9 | 3.068 | PL | 10.00 | PF | 0.3 |
| 26 | | 32.0 | 0.0 | 20.4 | 0.0 | 4.0 | 100 | FTG | T | PE | 0.0 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | | 0.016 | TL | 20.71 | PV | |
| | Pipe: 23 | | | | | -138.1 | 3.068 | PL | 36.00 | PF | 1.4 |
| 27 | | 32.0 | 0.0 | 20.7 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 28 | | 32.0 | 0.0 | 22.2 | 0.0 | | 0.035 | TL | 41.00 | PV | |
| | Pipe: 24 | | | | | -138.1 | 3.068 | PL | 12.50 | PF | 0.6 |
| 28 | | 32.0 | 0.0 | 22.2 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 29 | | 32.0 | 0.0 | 22.8 | 0.0 | | 0.035 | TL | 17.50 | PV | |
| | Pipe: 25 | | | | | -138.1 | 3.068 | PL | 17.22 | PF | 0.8 |
| 29 | | 32.0 | 0.0 | 22.8 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 30 | | 32.0 | 0.0 | 23.6 | 0.0 | | 0.035 | TL | 22.22 | PV | |
| | Pipe: 26 | | | | | -138.1 | 3.068 | PL | 12.50 | PF | 0.6 |
| 30 | | 32.0 | 0.0 | 23.6 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 31 | | 32.0 | 0.0 | 24.2 | 0.0 | | 0.035 | TL | 17.50 | PV | |
| | Pipe: 27 | | | | | -138.1 | 3.068 | PL | 35.00 | PF | 1.4 |
| 31 | | 32.0 | 0.0 | 24.2 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 32 | | 32.0 | 0.0 | 25.6 | 0.0 | | 0.035 | TL | 40.00 | PV | |
| | Pipe: 28 | | | | | -138.1 | 3.068 | PL | 26.50 | PF | 1.1 |
| 32 | | 32.0 | 0.0 | 25.6 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 33 | | 32.0 | 0.0 | 26.7 | 0.0 | | 0.035 | TL | 31.50 | PV | |
| | Pipe: 29 | | | | | -138.1 | 3.068 | PL | 18.30 | PF | 0.8 |
| 33 | | 32.0 | 0.0 | 26.7 | 0.0 | 6.0 | 100 | FTG | E | PE | 0.0 |
| 34 | | 32.0 | 0.0 | 27.5 | 0.0 | | 0.035 | TL | 23.30 | PV | |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

| PIPE TAG | END | ELEV. | NOZ. | PT | DISC. | Q (GPM) | DIA (IN) | LENGTH | PRESS. | |
|----------|-------|-------|------|-------|-------|-----------|----------|--------|--------|----------|
| | NODES | (FT) | (K) | (PSI) | (GPM) | VEL (FPS) | HW (C) | (FT) | SUM. | |
| | | | | | | | FL/FT | | (PSI) | |
| Pipe: 30 | | | | | | -138.1 | 3.068 | PL | 18.85 | PF 0.8 |
| 34 | | 32.0 | 0.0 | 27.5 | 0.0 | 6.0 | 100 | FTG | E | PE 0.0 |
| 35 | | 32.0 | 0.0 | 28.3 | 0.0 | | 0.035 | TL | 23.85 | PV |
| Pipe: 31 | | | | | | -138.1 | 3.068 | PL | 5.10 | PF 0.6 |
| 35 | | 32.0 | 0.0 | 28.3 | 0.0 | 6.0 | 100 | FTG | T | PE 0.0 |
| 36 | | 32.0 | 0.0 | 28.9 | 0.0 | | 0.035 | TL | 15.81 | PV |
| Pipe: 32 | | | | | | 216.9 | 3.068 | PL | 64.77 | PF 6.1 |
| 36 | | 32.0 | 0.0 | 28.9 | 0.0 | 9.4 | 100 | FTG | T | PE 0.0 |
| 37 | | 32.0 | 0.0 | 22.8 | 0.0 | | 0.081 | TL | 75.48 | PV |
| Pipe: 33 | | | | | | 167.6 | 3.068 | PL | 11.00 | PF 1.0 |
| 37 | | 32.0 | 0.0 | 22.8 | 0.0 | 7.3 | 100 | FTG | 2E | PE 0.0 |
| 38 | | 32.0 | 0.0 | 21.7 | 0.0 | | 0.050 | TL | 20.99 | PV |
| Pipe: 34 | | | | | | 142.0 | 3.068 | PL | 6.25 | PF 0.4 |
| 38 | | 32.0 | 0.0 | 21.7 | 0.0 | 6.2 | 100 | FTG | E | PE 0.0 |
| 39 | | 32.0 | 0.0 | 21.3 | 0.0 | | 0.037 | TL | 11.25 | PV |
| Pipe: 35 | | | | | | 142.0 | 3.068 | PL | 3.00 | PF 0.5 |
| 39 | | 32.0 | 0.0 | 21.3 | 0.0 | 6.2 | 100 | FTG | T | PE 0.0 |
| 20 | | 32.0 | 0.0 | 20.8 | 0.0 | | 0.037 | TL | 13.71 | PV |
| Pipe: 36 | | | | | | -355.0 | 4.026 | PL | 2.50 | PF 0.5 |
| 36 | | 32.0 | 0.0 | 28.9 | 0.0 | 8.9 | 100 | FTG | E | PE 0.0 |
| 40 | | 32.0 | 0.0 | 29.4 | 0.0 | | 0.053 | TL | 9.64 | PV |
| Pipe: 37 | | | | | | 355.0 | 4.026 | PL | 30.00 | PF 3.2 |
| 41 | | 2.0 | 0.0 | 45.6 | 0.0 | 8.9 | 100 | FTG | TGD | PE -13.0 |
| 40 | | 32.0 | 0.0 | 29.4 | 0.0 | | 0.053 | TL | 59.98 | PV |
| Pipe: 38 | | | | | | -355.0 | 7.981 | PL | 6.00 | PF 0.0 |
| 41 | | 2.0 | 0.0 | 45.6 | 0.0 | 2.3 | 120 | FTG | ---- | PE 0.0 |
| 42 | | 2.0 | 0.0 | 45.6 | 0.0 | | 0.001 | TL | 6.00 | PV |
| Pipe: 39 | | | | | | -355.0 | 7.981 | PL | 2.00 | PF 0.0 |
| 42 | | 2.0 | 0.0 | 45.6 | 0.0 | 2.3 | 120 | FTG | E | PE 0.0 |
| 43 | | 2.0 | 0.0 | 45.6 | 0.0 | | 0.001 | TL | 20.00 | PV |
| Pipe: 40 | | | | | | -355.0 | 7.981 | PL | 2.00 | PF 0.0 |
| 43 | | 2.0 | 0.0 | 45.6 | 0.0 | 2.3 | 120 | FTG | E | PE 0.9 |
| 44 | | 0.0 | 0.0 | 46.5 | 0.0 | | 0.001 | TL | 20.00 | PV |
| Pipe: 41 | | | | | | -355.0 | 7.981 | PL | 2.00 | PF 0.0 |
| 44 | | 0.0 | 0.0 | 46.5 | 0.0 | 2.3 | 120 | FTG | ---- | PE 0.0 |
| BFP-OUT | | 0.0 | 0.0 | 46.5 | 0.0 | | 0.001 | TL | 2.00 | PV |
| Pipe: 42 | | | | | | | | | | |
| BFP-IN | | 0.0 | 0.0 | 51.5 | 0.0 | | 5.0 | psi, | 355.0 | gpm |
| BFP-OUT | | 0.0 | 0.0 | 46.5 | 0.0 | | | | | |
| Pipe: 43 | | | | | | -355.0 | 7.981 | PL | 4.00 | PF 0.0 |
| BFP-IN | | 0.0 | 0.0 | 51.5 | 0.0 | 2.3 | 120 | FTG | E | PE 0.0 |
| 45 | | 0.0 | 0.0 | 51.6 | 0.0 | | 0.001 | TL | 22.00 | PV |
| Pipe: 44 | | | | | | -355.0 | 7.981 | PL | 5.00 | PF 0.0 |
| 45 | | 0.0 | 0.0 | 51.6 | 0.0 | 2.3 | 120 | FTG | E | PE 2.2 |
| 46 | | -5.0 | 0.0 | 53.8 | 0.0 | | 0.001 | TL | 23.00 | PV |

DATE: 4/28/2025HYDRAULICCALCULATIONS\WORKING\DRY SYSTEM INCLUDING BFP.SDF
 JOB TITLE:

| PIPE TAG | Q (GPM) | DIA (IN) | LENGTH | PRESS. |
|--|---------|----------|--------|--------|
| END ELEV. NOZ. PT DISC. VEL (FPS) HW (C) (FT) SUM. | | | | |
| NODES (FT) (K) (PSI) (GPM) FL/FT (PSI) | | | | |
| Pipe: 45 | -355.0 | 7.981 PL | 82.00 | PF 0.1 |
| 46 | 2.3 | 120 FTG | ---- | PE 0.0 |
| SRC | (N/A) | 0.001 TL | 82.00 | PV |

NOTES (HASS):

- (1) Calculations were performed by the HASS computer program in accordance with NFPA (2020) under license no. 65699794 granted by HRS Systems, Inc. 208 Southside Square Petersburg, TN 37144 (931) 659-9760
- (2) The system has been calculated to provide an average imbalance at each node of 0.001 gpm and a maximum imbalance at any node of 0.059 gpm.
- (3) Total pressure at each node is used in balancing the system. Maximum water velocity is 18.3 ft/sec at pipe 13.
- (4) Items listed in bold print on the cover sheet are automatically transferred from the calculation report.
- (5) Available pressure at source node SRC under full flow conditions is 59.35 psi with a flow of 384.59 gpm.
- (6) PIPE FITTINGS TABLE


HASS Pipe Table Name: standard

PAGE: A MATERIAL: S40 HWC: 120


| Diameter (in) | Equivalent Fitting Lengths in Feet | | | | | | | | | |
|---------------|------------------------------------|-------|-------|-------|----------|----------|----------|----------|---------|-------|
| | E Ell | T Tee | L Lng | C Ell | B ChkVlv | G BfyVlv | A GatVlv | D AlmChk | N DPVlv | T Tee |
| 1.049 | 2.00 | 5.00 | 2.00 | 5.00 | 6.00 | 1.00 | 10.00 | 2.00 | 5.00 | |
| 1.380 | 3.00 | 6.00 | 2.00 | 7.00 | 6.00 | 1.00 | 10.00 | 10.00 | 6.00 | |
| 3.068 | 7.00 | 15.00 | 5.00 | 16.00 | 10.00 | 1.00 | 13.00 | 13.00 | 15.00 | |
| 4.026 | 10.00 | 20.00 | 6.00 | 22.00 | 12.00 | 2.00 | 20.00 | 20.00 | 20.00 | |
| 7.981 | 18.00 | 35.00 | 13.00 | 45.00 | 12.00 | 4.00 | 31.00 | 31.00 | 35.00 | |

WATER SUPPLY ANALYSIS

Static: 60.00 psi Resid: 55.00 psi Flow: 1160.0 gpm



WATER SUPPLY CURVE





Model 350DA

Double Check Detector Assembly

Application

Designed for installation on water lines in fire protection systems to protect against both backsiphonage and backpressure of polluted water into the potable water supply. Model 350DA shall provide protection where a potential health hazard does not exist. Incorporates metered by-pass to detect leaks and unauthorized water use.

Standards Compliance

(Sizes 2 1/2" - 10" Horiz. & Vert.)
(12" Horizontal Only)

- ASSE® Listed 1048 (Sizes 2 1/2" thru 12")
- CSA® Certified B64.5 (Sizes 2 1/2" thru 8", & 12")
- AWWA Compliant C510 (Sizes 2 1/2" thru 12"), and C550
- UL® Classified (Sizes 2 1/2" thru 12")
- C-UL® Classified (Sizes 2 1/2" thru 12")
- FM® Approved (Sizes 2 1/2" thru 10")
- NYC MEA 147-99-M Vol 4 (2-1/2" - 10)
- Approved by the Foundation for Cross Connection Control and Hydraulic Research at the University of Southern California (Sizes 2 1/2" thru 12")
- Meets the requirements of NSF/ANSI/CAN 61*
*(0.25% MAX. WEIGHTED AVERAGE LEAD CONTENT)

By-Pass Backflow Assembly 3/4" Model 950XLD

Materials


| | |
|-----------------|--|
| Main valve body | Ductile Iron ASTM A 536 |
| Access covers | Ductile Iron ASTM A 536 |
| Coatings | NSF Approved fusion epoxy finish |
| Internals | Stainless steel, 300 Series NORYL™ |
| Fasteners | Stainless Steel, 300 Series |
| Elastomers | EPDM (FDA approved) Buna Nitrile (FDA approved) |
| Polymers | NORYL™ |
| Springs | Stainless Steel, 300 Series |

Dimensions & Weights (do not include pkg.)

| MODEL 350ADA SIZE | WEIGHT | | | | | | | | | |
|-------------------------|----------------------|-----|--------------------------|------|--------------------------|------|--------------------------|-----|------|----|
| | LESS SHUT-OFF VALVES | | OS&Y GATE VALVES FLANGED | | OS&Y GATE VALVES GROOVED | | BUTTERFLY VALVES GROOVED | | | |
| | in. | mm | lbs. | kg | lbs. | kg | lbs. | kg | lbs. | kg |
| 2 1/2 | 65 | 68 | 31 | 178 | 81 | 160 | 73 | 140 | 64 | |
| 3 | 80 | 68 | 31 | 198 | 90 | 150 | 68 | 120 | 54 | |
| 4 | 100 | 106 | 48 | 296 | 134 | 282 | 128 | 190 | 86 | |
| 6 | 150 | 180 | 82 | 480 | 218 | 454 | 206 | 298 | 135 | |
| 8 | 200 | 374 | 170 | 850 | 386 | 802 | 364 | 548 | 249 | |
| 10 | 250 | 404 | 183 | 1222 | 554 | 1156 | 524 | 792 | 359 | |
| 12 | 300 | 463 | 210 | 1623 | 736 | n/a | n/a | n/a | n/a | |

Attention:
Model 350DA (flange body) and Model 350ADA (grooved body) have different lay lengths.

| MODEL 350DA SIZE | DIMENSION (approximate) | | | | | | | | | | | | | | | | | | | | |
|------------------------|-------------------------|---------|-------------------------|--------|--------------------|--------|-----|-------|-----|--------|-------------|--------|---------------|--------|-------------------------|----------|-----|-------|-----|--------|-----|
| | A | | A WITH BUTTERFLY VALVES | | B LESS GATE VALVES | | C | | D | | E OS&Y OPEN | | E OS&Y CLOSED | | E WITH BUTTERFLY VALVES | | F | | G | | |
| | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | |
| 2 1/2 | 65 | 31 | 787 | 28 | 711 | 15 7/8 | 403 | 3 3/4 | 95 | 9 | 229 | 17 3/4 | 451 | 15 3/8 | 391 | 13 3/4 | 349 | 3 1/2 | 89 | 7 1/4 | 184 |
| 3 | 80 | 32 | 813 | 28 1/2 | 724 | 15 7/8 | 403 | 3 3/4 | 95 | 9 | 229 | 20 1/4 | 514 | 17 | 432 | 13 3/4 | 349 | 3 1/2 | 89 | 7 1/4 | 184 |
| 4 | 100 | 37 5/8 | 956 | 32 8/9 | 835 | 19 1/2 | 495 | 4 1/2 | 114 | 9 | 229 | 22 1/2 | 572 | 18 1/4 | 464 | 17 | 432 | 6 | 152 | 8 | 203 |
| 6 | 150 | 44 5/8 | 1133 | 37 5/8 | 956 | 23 1/2 | 597 | 6 | 152 | 10 1/2 | 267 | 30 1/2 | 775 | 24 1/4 | 616 | 17 1/2 | 445 | 7 | 178 | 10 | 254 |
| 8 | 200 | 60 7/8 | 1546 | 53 7/8 | 1369 | 37 3/4 | 959 | 10 | 254 | 12 | 305 | 37 | 940 | 28 1/2 | 724 | 16 15/16 | 430 | 8 1/2 | 216 | 11 | 279 |
| 10 | 250 | 63 7/8 | 1622 | 57 7/8 | 1470 | 37 3/4 | 959 | 10 | 254 | 12 | 305 | 45 5/8 | 1159 | 34 3/4 | 883 | 16 15/16 | 430 | 8 1/2 | 216 | 12 | 305 |
| 12 | 300 | 66 3/16 | 1681 | n/a | n/a | 38 | 965 | 10 | 254 | 12 | 305 | 53 | 1346 | 40 1/2 | 1029 | n/a | n/a | 8 7/8 | 226 | 16 3/4 | 425 |



Options

(Suffixes can be combined)


- with OS & Y gate valves (standard)
- L - less shut-off valves (flanged body connections)
- LM - less water meter
- with gallon meter (standard)
- CFM - with cu ft meter
- CMM - with cu meter meter
- G - with groove end gate valves
- FG - with flanged inlet connection and grooved outlet connection
- PI - with Post Indicator Gate Valve
- GF - with flanged inlet connection and grooved outlet connection
- BG - with grooved end butterfly valves with integral monitor switches (2 1/2" - 10")

Accessories

- Repair kit (rubber only)
- Thermal expansion tank (Model XT)
- OS & Y Gate valve tamper switch (OSY-40)


Features

- Sizes: 2 1/2", 3", 4", 6", 8", 10", 12"
- Maximum working water pressure: 175 PSI
- Maximum working water temperature: 140°F
- Hydrostatic test pressure: 350 PSI
- End connections (Grooved for steel): AWWA C606
- (Flanged bolt pattern): ASME B16.42 Class 150




MODEL 350DAG SHOWN ABOVE


MODEL 350DA 2 1/2", 3" & 4" (STANDARD & METRIC)



MODEL 350DA 6" & 8" (STANDARD & METRIC)




MODEL 350DA 10" & 12" (STANDARD & METRIC)




Typical Installation

Local codes shall govern installation requirements. Unless otherwise specified, the assembly shall be mounted at a minimum of 12" (305mm) and a maximum of 30" (762mm) above adequate drains with sufficient side clearance for testing and maintenance. The installation shall be made so that no part of the unit can be submerged.



VERTICAL INSTALLATION



OUTDOOR INSTALLATION

| Capacity thru Schedule 40 Pipe (GPM) | | | | |
|--------------------------------------|----------|------------|-----------|-----------|
| Pipe size | 5 ft/sec | 7.5 ft/sec | 10 ft/sec | 15 ft/sec |
| 2 1/2" | 75 | 112 | 149 | 224 |
| 3" | 115 | 173 | 230 | 346 |
| 4" | 198 | 298 | 397 | 595 |
| 6" | 450 | 675 | 900 | 1351 |
| 8" | 780 | 1169 | 1559 | 2339 |
| 10" | 1229 | 1843 | 2458 | 3687 |
| 12" | 1763 | 2644 | 3525 | 5288 |

Specifications

The Double Check Detector Backflow Prevention Assembly shall be certified to NSF/ANSI/CAN 61, ASSE® Listed 1048, and supplied with full port gate valves. The main body and access cover shall be epoxy coated ductile iron (ASTM A 536), the seat ring and check valve shall be Noryl™, the stem shall be stainless steel (ASTM A 276) and the seat disc elastomers shall be EPDM. The first and second check valves shall be accessible for maintenance without removing the device from the line. The Double Check Detector Backflow Prevention Assembly shall be a ZURN WILKINS Model 350DA.

April 3, 2025
Via Email

BMI ENGINEERING INC.

c/o: BIJAN HOMAYOUNI
5000 Yonge St E Bldg 1901
Toronto, ON
M2N 7E9

Dear BIJAN:

RE: Notice of Building Review Deficiencies
Permit Application: 2025 031148 000 00
Applied For On: February 28, 2025
Address of Work: 2691 Sandalwood Pky E
Scope of Work: TENANT - FIRE STATION 209
Mechanical equipment replacement and upgrade
including installation of two new backflow preventers

Please be advised that the Architectural and Structural review of your application was completed on Thursday, April 3, 2025.

To bring this submission into compliance with the Building Code Act, S.O. 1992, c.23 and the Ontario Building Code 2012, as amended, the following deficiencies need to be addressed or information is required:

Deficiencies:

1. Submit a sprinkler drawing and hydraulic calculations demonstrating that the installation of a backflow preventer will not adversely affect the existing sprinkler system, or a letter from a Professional Engineer clearly analyzing and outlining the hydraulic impact of the backflow preventer on the system.

Submission:

Please submit a revised submission(s) via Brampton Portal:
<https://bramptonbbp.brampton.ca/citizenportal/app/landing>

To streamline our review process and avoid duplication of effort, we kindly request that you upload the revised documents directly to our portal instead of emailing to an individual plans examiner. This approach will help ensure all submissions are properly logged and accessible to our team. We appreciate your help.

Inquiries about the Brampton Building and Business Portal can be directed to: building.inquiries@brampton.ca

Please note that the completion of the review and the issuance of a building permit is dependent upon the receipt of the above noted information. If you have questions specific to the deficiencies listed above, please contact the undersigned.

As the application proceeds through the next stages of review, you may receive additional notices of deficiency.

Yours truly,


Akemi Mizusawa
(905) 874-2476
Akemi.Mizusawa@brampton.ca

Please Note:

- It is illegal to commence construction without first having obtained a building permit.
- Where an application remains incomplete or inactive for a period of six months or more, the application will be deemed abandoned.

CC. CITY OF BRAMPTON - TALHA SHEIKH (owner)
2 Wellington St W Brampton ON L5W1E1


ELEV -5'
 SRC
 Incoming = 60 PSI
 Flow = 1160 gpm
 ELEV -5'



DESIGN DATA:


- Remote Area Location : Ground Floor
- Type : Wet System
- Hazard : Ordinary Hazard System - 1
- Design Density : 0.15 gpm / sq. ft
- Remote Area : 1500 sq. ft
- Number of Sprinklers in Remote Area : 12 Nos
- Sprinkler Classification : Quick Response (QR)
- Maximum sprinkler Coverage : 130 sq. ft
- Sprinkler K- Factor : K5.6

WET SYSTEM



DESIGN DATA:

- Remote Area Location : Attic Floor
- System Type : Dry System
- Hazard : Ordinary Hazard System - 1
- Design Density : 0.15 gpm / sq. ft
- Remote Area : 1950 sq. ft
- Number of Sprinklers in Remote Area : 15 Nos
- Sprinkler Classification : Quick Response Upright
- Maximum sprinkler Coverage : 130 sq. ft
- Sprinkler K- factor : K5.6



DRY SYSTEM

ELEV - 5'
 SRC
 Incoming = 60 PSI
 Flow = 1160 gpm